



STATE OF UTAH  
DEPARTMENT OF HEALTH

NORMAN H. BANGERTER, GOVERNOR

SUZANNE DANJOY, M.D., M.P.H., EXECUTIVE DIRECTOR

December 4, 1985  
533-6146

RECEIVED

DEC 06 1985

DIVISION OF OIL  
GAS & MINING

Trevor G. Whiteside  
Chief Engineer  
Valley Camp of Utah, Inc.  
Scofield Route  
Helper, Utah 84526

Re: Plan Approved, Sediment Pond 002

Dear Mr. Whiteside:

We have reviewed the plans and design information for the Valley Camp of Utah sediment pond 002. Plans C4-0060, B-3-0033 and the August 29, 1985 Vaughn Hansen Associates information were reviewed.


As a result of our review, it has been determined that the sediment pond revisions basically conform with the State Wastewater Disposal Regulations. This letter constitutes our approval for these pond revisions.

The pond is to provide a volume of 1.1 acre feet for the settling of suspended solids from the runoff of the 10 year 24 hour storm. The revisions include the raising of the emergency spillway one foot, raising the primary spillway 2.4 feet and adding a 3 inch decant. The sediment level is to be maintained at least two feet below the decant opening.

If the effluent does not meet State or Federal standards, the company must provide the necessary additional treatment. Discharges from the pond must be reported to this office as required in the NPDES permit.

Sincerely,

UTAH WATER POLLUTION CONTROL COMMITTEE

  
Calvin K. Sudweeks  
Executive Secretary

cc: Oil, Gas and Mining - Wayne Hedberg  
Southeastern Dist. Health Dept.  
Dave Ariotti

SRM:pa  
388-7