

0064

VALLEY CAMP OF UTAH, INC.

Scofield Route
Helper, Utah 84526

December 16, 1986

RECEIVED
DEC 22 1986

DIVISION OF
OIL, GAS & MINING

Mr. D. Wayne Hedberg
Division of Oil, Gas & Mining
355 West North Temple, Suite 350
3 Triad Center
Salt Lake City, UT 84180-1203

Re: Wash Bay Installation
Belina Complex

Dear Mr. Hedberg:

In correspondence to the Division dated October 21, 1986, you were informed of Valley Camp's plans to install a wash bay and a retaining wall at the Belina Complex. In that letter, we indicated that a 5,000 gallon holding tank would be installed with the wash bay, to act as a retention basin for the residue and water from the wash bay. At that time, I was attempting to obtain EPA approval for this installation and did not include the tank on the submitted drawing. This, apparently, is not required prior to installation of the tank.

Since I am unable to obtain anything but "general" installation directions from the various State and Federal agencies contacted, I am enclosing for your review, twelve (12) copies of the proposed construction-installation drawings (No. A4-0124) for the tank. The tank will be located approximately 30 feet north of the wash bay and 25 feet north east of the shop.

If you have questions or concerns pertaining to this installation, please contact me.

Sincerely,



Trevor G. Whiteside
Chief Engineer

TGW/gs

Enclosures

GRADE

BACKFILL TO GRADE


36" MIN.

EXISTING SOIL (UNDISTURBED)

END VIEW

NOTES:

- 1. VENT PIPE SYSTEM WILL SURFACE AT OR NEAR EXISTING SHOP BUILDING IN A PROTECTED AREA.
- 2. PIPING FROM TANK WILL BE PVC OR EQUIV. WITH CONNECTIONS TO METAL LINES AT SURFACE OUTLET.
- 3. SYSTEM WILL BE INSTALLED ACCORDING TO A.P.I. & C.F.R. STANDARDS.
- 4. CATHODIC PROTECTION SYSTEM WILL BE INSTALLED. ANODE POSITIONS MAY VARY TO GAIN MAXIMUM EFFICIENCY.



12" MIN. TRENCH COVER


ANCHOR PIN

2' MIN.

GRADE

36" MIN.

6' MIN.



FRONT VIEW

ANCHOR PIN

DRAWN BY:	J.A.U.
CHECKED BY:	
REVISED BY:	
APPROVAL ENG.:	
APPROVAL SAFETY:	
APPROVAL MINE:	

DATE:	12-5-86
DATE:	
SCALE:	



VALLEY CAMP of UTAH
SCOFIELD ROUTE
HELPER, UTAH 84526

TITLE:
BELINA MINE COMPLEX: WASH BAY STORAGE TANK, PROP. INSTALLATION

DRAWING NO.	REV. NO.
A4-0124	