


ACT/007/001

STATE OF UTAH
DEPARTMENT OF HEALTH

NORMAN H. BANGERTER, GOVERNOR

SUZANNE DANDY, M.D., M.P.H., EXECUTIVE DIRECTOR

January 22, 1987



Mr. Trevor Whiteside
Valley Camp of Utah, Inc.
Scofield Route
Helper, Utah 84526

DIVISION OF
OIL, GAS & MINING

Re: Belina Complex Wash Bay and
Holding Tank

Dear Mr. Whiteside:

We have reviewed Drawing Nos. B4-0038, A4-0124, D4-01267 and correspondence dated December 12, 1986 and January 15, 1987. Based upon our review, we offer the following recommendations and explanations thereof:

1. No provisions for emptying the storage tank be provided other than removal by the disposal contractor. Provision of a pump in the storage tank increases the possibility of an unauthorized discharge.
2. Provisions for collection and storage of waste oil and wash water should be separate. Waste oil can contain hazardous materials such as chrome, lead and organics. Samples should be collected and analyzed. If the oil is found to contain hazardous materials, all material with which the oil is mixed may be considered hazardous. This will limit disposal options and dictate construction standards which the holding tank must meet.

If you have any questions, please do not hesitate to call.

Sincerely,

David R. Ariotti, P.E.
District Engineer
Division of Environmental Health

DRA

c: Oil, Gas and Mining
Don Ostler, Bureau of Water Pollution Control
Scott Andersen, Bureau of Solid and Hazardous Waste

KENNETH L. ALKEMA, DIRECTOR • DIVISION OF ENVIRONMENTAL HEALTH