

0058

UTAH POWER & LIGHT COMPANY

1407 WEST NORTH TEMPLE STREET

P. O. BOX 899

SALT LAKE CITY, UTAH 84110

January 7, 1983

RECEIVED

JAN 10 1983

DIVISION OF
OIL, GAS & MINING

Mr. Thomas N. Tetting
State of Utah
Division of Oil, Gas & Mining
4241 State Office Building
Salt Lake City, Utah 84114


RE: Modification to the Truck Turnaround
at the Price River Coal Company
Your ACT/007/004
Carbon County, Utah

Dear Mr. Tetting:

We are submitting revised McNally Engineering Drawings C-1001, Rev. C and C-1002, Rev. A intended to satisfy your concerns regarding adequate rip rap at the culvert area and concerning adherence to a maximum slope of 1.5:1 at the culvert area. Please note that Gabion Baskets are to be used as support material at the culvert area in order to accomplish the required slope of fill material.

We will start construction upon receipt of your approval of our proposed methods of construction. Please review the enclosed drawings and respond with a verbal and written approval at your earliest convenience. If you have questions, contact Mr. Tom Needs at 535-2510.

Sincerely,



R. A. Clawson
Plant Projects Supervisor

RAC/TJN/cd

Enclosures