



**Coastal**  
The Energy People

0055

September 12, 1991

Rec: Route to F. G.  
Act/007/005 #7

RECEIVED

SEP 13 1991

DIVISION OF  
OIL GAS & MINING

Mr. Michael Reed  
U.S. Environmental Protection Agency  
Water Management Division (8WM-C)  
1 Denver Place, Suite 500  
999 - 18th Street  
Denver, Colorado 80202-2413

RE: NPDES PERMIT UT-0023540

Dear Mr. Reed:

In accordance with the conditions of NPDES Discharge Permit UT-0023540, Part II - A-2 and Utah Mining Code Section 817.52(b)(i)(ii), Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS and Sulfate at the 001 discharge point.

The problem occurred with the sample taken July 25, 1991, which had a TDS concentration of 1377 mg/l and a Sulfate concentration of 1000 mg/l. These concentrations exceed the 1000 mg/l maximum limitation for TDS and the 500 mg/l maximum Sulfate limitation established in the current NPDES discharge permit. The laboratory report was received on September 12, 1991.

Sincerely,

*Keith W. Welch*

Keith W. Welch  
Environmental Coordinator

KWW/ak/2400

xc: Division of Oil, Gas & Mining  
Glen A. Zumwalt  
Keith Zobell

Department of Environmental Health  
Ken May

**Coastal States Energy Company**

A SUBSIDIARY OF THE COASTAL CORPORATION  
175 E. 400 SOUTH, SUITE 800 • SALT LAKE CITY • UTAH 84111