



Coastal
The Energy People

0009

Rick Route to file
ACT/007/005
#17
RECEIVED
FEB 03 1992
DIVISION OF
OIL GAS & MINING

January 30, 1992

Mr. Don Ostler, Bureau Director
State of Utah
Division of Water Quality
Department of Environmental Quality
Salt Lake City, Utah 84114-4870

RE: NPDES PERMIT UT-0023540

Dear Mr. Ostler:

In accordance with the conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Mining Code Section 817.52(b)(i)(ii), Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken December 11, 1991, which had a TDS concentration of 1400 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report received on December 26, 1991, erroneously reported the TDS concentration within limits. The subsequent corrected report showed the exceedence as noted.

Sincerely,

Keith W. Welch

Keith W. Welch
Environmental Coordinator

KWW/ak/2400

xc: Division of Oil, Gas & Mining
Glen A. Zumwalt
Keith Zobell

Michael Reed, EPA
Ken May