



**Coastal**  
The Energy People

Route to File  
Ad/007/005 #7

RECEIVED

JUN 15 1992

DIVISION OF  
OIL GAS & MINING

0056

June 11, 1992

Mr. Don Ostler, Bureau Director  
State of Utah  
Division of Water Quality  
Department of Environmental Quality  
Salt Lake City, Utah 84114-4870

RE: NPDES PERMIT UT-0023540

Dear Mr. Ostler:

In accordance with conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken May 19, 1992, which had a TDS concentration of 1274 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report was received on June 9, 1992.

Sincerely,

*Keith W. Welch*

Keith W. Welch  
Environmental Coordinator

KWW/gb/423

cc: Division of Oil, Gas & Mining ✓  
Glen A. Zumwalt  
Keith Zobell  
Michael Reed, EPA  
Ken May

**Utah Fuel Company**

A SUBSIDIARY OF THE COASTAL CORPORATION  
P O BOX 719 • HELPER UT 84526 • 801 637-7925 • FAX 801 637-7929  
SALT LAKE 801 596-7111