



Coastal
The Energy People

*Per - failure to file
Act/002/005
27*

RECEIVED

OCT 13 1992

**DIVISION OF
OIL, GAS & MINING**

0106

October 9, 1992

Mr. Don Ostler, Bureau Director
State of Utah
Division of Water Quality
Department of Environmental Quality
Salt Lake City, Utah 84114-4870

Dear Mr. Ostler:

RE: NPDES PERMIT UT-0023540

In accordance with conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken September 22, 1992, which had a TDS concentration of 1115 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report was received on October 5, 1992.

Sincerely,

Keith W. Welch by gb

Keith W. Welch
Environmental Coordinator

KWW/gb/423

cc: Division of Oil, Gas & Mining ✓
Glen A. Zumwalt
Keith Zobell
Michael Reed, EPA
Ken May
Craig Hilton

Utah Fuel Company

A SUBSIDIARY OF THE COASTAL CORPORATION
P. O. BOX 719 • HELPER UT 84526 • 801 637-7925 • FAX 801 637-7929
SALT LAKE 801 596-7111