



**Coastal**  
The Energy People

Route To File  
A1/009/005-27

RECEIVED

OCT 30 1992

DIVISION OF  
OIL GAS & MINING

0112

October 27, 1992

Mr. Don Ostler, Bureau Director  
State of Utah  
Division of Water Quality  
Department of Environmental Quality  
Salt Lake City, Utah 84114-4870

Dear Mr. Ostler:

**RE: NPDES PERMIT UT-0023540**

In accordance with the conditions of NPDES Discharge Permit UT-0023540, Part II-I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the written notification of a failure to comply with the maximum effluent limitations for TDS and Sulfate at the 001 discharge point.

The problem occurred with the sample taken September 30, 1992, which had a TDS concentration of 1218 mg/l, and a sulfate concentration of 900 mg/l. These concentrations exceed the 1000 mg/l maximum limitation for TDS and the 500 mg/l maximum Sulfate limitation established in the current NPDES discharge permit. The laboratory report was received on October 27, 1992.

Sincerely,

Keith W. Welch  
Environmental Coordinator

KWW/gb/424

cc: ~~Division of Oil, Gas & Mining~~

Michael Reed, EPA  
Glen Z. Zumwalt  
Ken May  
Keith Zobell

**Utah Fuel Company**

A SUBSIDIARY OF THE COASTAL CORPORATION  
P O BOX 719 • HELPER UT 84526 • 801 637-7925 • FAX 801 637-7929  
SALT LAKE 801 596-7111