




Coastal
The Energy People

August 18, 1994

Mr. Don Ostler, Director
Division of Water Quality
Department of Environmental Quality
State of Utah
Salt Lake City, Utah 84114-4870

Re: NPDES Permit UT-0023540



Route to Don Ostler
Route to Copy PFO
Ken file ACT/002/005 #2

Dear Mr. Ostler,

In accordance with condition of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TSS at the 001 discharge point.

The problem occurred with the samples taken during June, 1994 which had a TSS monthly concentration of 33.5 Mg/l. This concentration exceeds the 25 Mg/l average limitation for TSS established in the current NPDES discharge permit. The last laboratory report for July was received on August 18, 1994.

Sincerely,

Keith W. Welch
Environmental Coordinator
Utah Fuel Company

KW:dk

cc: Division of Oil, Gas & Mining
Ken Payne
Keith Zobell
Micheal Reed, EPA
Craig Hilton

DWQ0818.KW

Utah Fuel Company

A SUBSIDIARY OF THE COASTAL CORPORATION
P O BOX 719 • HELPER UT 84526-0719 • 801/637-7925 • FAX 801/637-7929 • SALT LAKE 801/596-7111