

0040

007/005 #7

RECEIVED

FEB 14 1994



Coastal
The Energy People

DIVISION OF
OIL GAS & MINING

February 11, 1994

Mr. Don Ostler, Director
Division of Water Quality
Department of Environmental Quality
State of Utah
Salt Lake City, Utah 84114-4870

Re: NPDES Permit UT-0023540

Dear Mr. Ostler,

In accordance with condition of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken February 3, 1994, which had a TDS concentration of 1003 Mg/l. This concentration exceeds the 1000 Mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report was received on February 10, 1994.

Sincerely,

for
Keith W. Welch
Environmental Coordinator
Utah Fuel Company

KW/dk

cc: Division of Oil, Gas & Mining
Ken Payne
Keith Zobell
Micheal Reed, EPA
Craig Hilton

MEM00124.KW

Utah Fuel Company

A SUBSIDIARY OF THE COASTAL CORPORATION
P.O. BOX 719 • HELPER UT 84526-0719 • 801-637-2915 • FAX 801-637-2919 • SALT LAKE CITY 801-596-1111