0047

Route to: Dave

007/005 #7

Coastal
The Energy People

RECEIVED
JAN 07 1994
DIVISION OF
OIL, GAS & MINING

January 4, 1994

Mr. Don Ostler, Director
Division of Water Quality
Department of Environmental Quality
State of Utah
Salt Lake City, Utah 84114-4870

Dear Mr. Ostler:

RE: NPDES PERMIT UT-0023540

In accordance with conditions of NPDES Discharge Permit UT-0023540, Part II - I-3 and Utah Coal Mining Rules R645-301-731.223, Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for TDS at the 001 discharge point.

The problem occurred with the sample taken December 14, 1993, which had a TDS concentration of 1042 mg/l. This concentration exceeds the 1000 mg/l maximum limitation for TDS established in the current NPDES discharge permit. The laboratory report was received on January 3, 1994.

Sincerely,

Keith W. Welch

Keith W. Welch
Environmental Coordinator

KWW/gb/425

xc: Division of Oil, Gas & Mining
Ken Payne
Keith Zobell
Michael Reed, EPA
Craig Hilton

Utah Fuel Company
A SUBSIDIARY OF THE COASTAL CORPORATION
P.O. BOX 719 • HELPER UT 84526-0719 • 801 637 7005 • FAX 801 637 7009 • SALT LAKE 801 596 7111