




**Coastal**  
The Energy People

August 28, 1996

Mr. Don Ostler, Director  
Division of Water Quality  
Division of Environmental Quality  
State of Utah  
Salt Lake City, Utah 84114-4870

**RE: UPDES Permit UT-0023540**

Dear Mr. Ostler:



~~Fax Steve @ PFO Ken~~  
Ken, then fill  
ACT/007/005 #7

Utah Fuel Company is providing the required written notification of a failure to comply with maximum seven day average limitation for total suspended solids according to UPDES Discharge Permit UT-00235540, Part II 1-3 and Utah Coal Mining Rules R645-301-731.223. The failure occurred at discharge point 001 .

The problem occurred with the sample taken 8 August 1996, which had a total suspended solids concentration of 60 mg/l which exceeds the maximum seven-day of 35 mg/l. The laboratory report was received on 27 August 1996. The suspended solids problem occurred while cleaning out the sedimentation pond the week before. The cleaning process stirred up the fine sediments in the pond. Utah Fuel Company is correcting the problem by injecting a flocculent into the pond to help settle the solids.

Sincerely,

*Gary E. Taylor*

Gary Taylor  
Sr. Mining Engineer  
Utah Fuel Company

cc: Division of Oil, Gas & Mining  
Michael Reed  
Ken Payne Barry Barnum  
Keith Zobell Craig Hilton

y:\wp6\LDWQ827

**Utah Fuel Company**

A SUBSIDIARY OF THE COASTAL CORPORATION  
P O BOX 719 • HELPER UT 84526-0719 • 801/637-7925 • FAX 801/637-7929 • SALT LAKE 801/596-7111