

From: Gregg Galecki
To: Daron Haddock; Mary Ann Wright; Pam Grubaugh-Littig; Susan White
Date: 9/18/03 2:16PM
Subject: JC-1 Well

FYI-

Chris Hansen just informed me JC-1 Well shut down 17Sept03 am. The motor apparently burned up. Coorespondingly the pumping of JC-3 increased from 4,000 gpm to 6,000 gpm, apparently due to the reduced head in the discharge pipe. No telling how long it will be down or what PACIFICORP will decide to do with repairs. According to the in-line conductivity meter, the TDS remains stable (but still an exceedance).