



Canyon Fuel Company, LLC
Skyline Mines
HC 35 Box 380
Helper, Utah 84526
(435) 448-6463 Fax: (435) 448-2632

July 27, 2004

Coal Regulatory Program
Attn.: Pam Grubaugh-Littig
Division of Oil, Gas and Mining
1594 West North Temple, Suite 1210
Box 145801
Salt Lake City, Utah 84114-5801

*Incoming
C/007/0005
Copy Letter to
Grubaugh/H/gregg*

RE: June 2004 JC-3 DMRs, Skyline Mine, Canyon Fuel Company, LLC Skyline Mine, C/007/005.

Dear Pam:

Please find attached to this letter the DMRs for the JC-3 well for June 2004. According to the PacifiCorp reports the total iron and TDS limits were exceeded. Consequently, PacifiCorp has discontinued pumping from JC-3 until either the water meets their UPDES limits or their permit is changed. Also, there has been an equipment malfunction at JC-3 that has not yet been repaired. If you have any questions regarding this information, please call me at (435) 448-2669.

Sincerely:

Chris D. Hansen
Environmental Coordinator
Canyon Fuel Company, LLC.

attachments

RECEIVED

JUL 29 2004

DIV. OF OIL, GAS & MINING



Huntington Plant

P.O. Box 680

Huntington, Utah 84528

July 21, 2004

Department of Environmental Quality

Division of Water Quality

Attn: Mike Herkimer

288 North 1460 West

P.O. Box 144870

Salt Lake City, Utah 84114-4870

**Re: Huntington Plant – James Canyon Well System UPDES Permit #UT0025534 DMR
for June 2004**

Dear: Mr. Herkimer:

In accordance with the James Canyon Well System UPDES permit (#UT0025534) Section II.D. Reporting of Monitoring Results, PacifiCorp is hereby submitting a Daily Monitoring Report (DMR) for the period June 1, 2004 to June 30, 2004.

This DMR is being submitted with the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

We were unable to obtain June results for total arsenic due to lab instrumentation malfunction. June samples exceeded permit limits for TDS (373 with a limit of 255) and total iron (0.94 with a limit of 0.5). Consequently, we have discontinued pumping from well JC-3 pending resolution of this compliance issue. If you have any questions and/or need any additional information, please contact Cody Allred at (435) 687-4306 or Dave Sharp at (435) 687-4211.

Sincerely,

A handwritten signature in black ink, appearing to read "Dave Sharp".

Dave Sharp

Managing Director – PacifiCorp Huntington Plant

Enclosures

cc: Chris Hansen – Canyon Fuels Company - Skyline Mine (w/encl.)

PERMITEE NAME/ADDRESS

NAME **James Canyon Well System**
 ADDRESS **P.O.Box 680**
Huntington, Utah 84528

FACILITY **James Canyon Well System**
 LOCATION **Huntington, Utah 84528**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

Form Approved
 OMB No. 2040-0004

UT0025534
 PERMIT NUMBER

001 A
 DISCHARGE NUMBER

MINOR

F-FINAL
 JC-3 PUMPING PLATFORM TO LAKE

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0	4	0	6	0	1
0	4	0	6	3	0

*** NO DISCHARGE ***

ATTN: Darce Guymon (PROJECT REPRESENTATIVE)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE (AS AG) 00056 1 0 0 EFFLUENT GROSS VALUE	REPORT 30DA AVG	5750		(78)	*****	*****	*****	*****		1/30	INSTANT
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	7.30	*****	7.71	(12)		2/30	GRAB
OIL AND GREASE, HEXANE EXTR METHOD 00552 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	6.5 DAILY MN	*****	9.0 DAILY MX	SU		ONCE/MONTH	GRAB
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.1	0.1	(19)		1/30	GRAB
NITRITE PLUS NITRATE TOTAL 1 DET (AS N) 00630 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB
PHOSPHORUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.05	<0.05	(19)		1/30	GRAB
PHOSPHORUS, DISSOLVED 00666 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER
DAVE SHARP
 MANAGING DIRECTOR, PLANT
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Darce Guymon
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 435 687-4306
 DATE
 7/22/2004
 AREA CODE NUMBER YR MO DA

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITEE NAME/ADDRESS

NAME **James Canyon Well System**
 ADDRESS **P.O.Box 680**
Huntington, Utah 84528

FACILITY **James Canyon Well System**
 LOCATION **Huntington, Utah 84528**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

Form Approved
 OMB No. 2040-0004

UT0025534
 PERMIT NUMBER

001 A
 DISCHARGE NUMBER

MINOR


F-FINAL
 JC-3 PUMPING PLATFORM TO LAKE

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0	4	0	6	0	1
0	4	0	6	3	0

*** NO DISCHARGE ***

ATTN: Darce Guymon (PROJECT REPRESENTATIVE)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
ARSENIC, DISSOLVED (AS AS) 01000 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.010	<0.010	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
ARSENIC, TOTAL (AS AS) 01002 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.010	<0.010	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
CADMIUM, DISSOLVED (AS CD) 01025 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.001	<0.001	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
CADMIUM, TOTAL (AS CD) 01027 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.001	<0.001	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
CHROMIUM, DISSOLVED (AS CR) 01030 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.001	<0.001	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
CHROMIUM, TOTAL (AS CR) 01034 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	0.001	0.001	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB
COPPER, DISSOLVED (AS CU) 01040 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	*****	*****	<0.01	<0.01	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L		ONCE/MONTH	GRAB

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER DAVE SHARP MANAGING DIRECTOR, PLANT TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE	
			435	687-4306	7/22/2004	
COMMENT AND EXPLANATION OF ANY VIOLATIONS	(Reference all attachments here)	AREA CODE	NUMBER	YR	MO	DA

PERMITEE NAME/ADDRESS

NAME **James Canyon Well System**
 ADDRESS **P.O.Box 680**
Huntington, Utah 84528

FACILITY **James Canyon Well System**
 LOCATION **Huntington, Utah 84528**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

Form Approved
 OMB No. 2040-0004

UT0025534
 PERMIT NUMBER

001 A
 DISCHARGE NUMBER

MINOR

F-FINAL
 JC-3 PUMPING PLATFORM TO LAKE

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 4	0 6	0 1	0 4	0 6	3 0

*** NO DISCHARGE ***

ATTN: Darce Guymon (PROJECT REPRESENTATIVE)

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS	
COPPER, TOTAL (AS CU) 01042 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			(78)	*****	<0.01	<0.01	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPM	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
IRON, TOTAL (AS FE) 01045 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	0.94	(19)	1	2/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	0.5	MGL		ONCE/MONTH	GRAB	
IRON, DISSOLVED (AS FE) 01046 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.03	<0.03	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
LEAD, DISSOLVED (AS PB) 01049 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.01	<0.01	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
LEAD, TOTAL (AS PB) 01051 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.01	<0.01	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
NICKEL, DISSOLVED (AS NI) 01065 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.001	0.001	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
NICKEL, TOTAL (AS NI) 01067 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.001	0.001	(19)		1/30	GRAB	
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MGL		ONCE/MONTH	GRAB	
NAME/TITLE PRINCIPLE EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.							TELEPHONE		DATE		
DAVE SHARP MANAGING DIRECTOR, PLANT								435	687-4306	7/22/2004		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YR	MO	DA
COMMENT AND EXPLANATION OF ANY VIOLATIONS	(Reference all attachments here)											

PERMITEE NAME/ADDRESS

NAME **James Canyon Well System**
 ADDRESS **P.O.Box 680**
Huntington, Utah 84528

FACILITY **James Canyon Well System**
 LOCATION **Huntington, Utah 84528**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

Form Approved
 OMB No. 2040-0004

UT0025534
 PERMIT NUMBER

001 A
 DISCHARGE NUMBER

MINOR


F-FINAL
 JC-3 PUMPING PLATFORM TO LAKE

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 4	0 6	0 1	0 4	0 6	3 0

*** NO DISCHARGE ***

ATTN: Darce Guymon (PROJECT REPRESENTATIVE)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
SILVER, DISSOLVED (AS AG) 01075 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			(78)	*****	<0.002	<0.002	(19)	1/30	GRAB
	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPM	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
SILVER, TOTAL (AS AG) 01077 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.002	<0.002	(19)	1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
ZINC, DISSOLVED (AS ZN) 01090 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.004	<0.004	(19)	1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
ZINC, TOTAL (AS ZN) 01092 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.011	0.011	(19)	1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
SELENIUM, DISSOLVED (AS SE) 01145 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.02	<0.02	(19)	1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
SELENIUM, TOTAL (AS SE) 01147 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.02	<0.02	(19)	1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	ONCE/MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL 45613 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	(94)	*****	*****	*****	*****	1/30	VISUAL
	PERMIT REQUIREMENT	*****	0	YES = 1 NO = 0	*****	*****	*****	*****	ONCE/MONTH	VISUAL

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE	
DAVE SHARP MANAGING DIRECTOR, PLANT			435	687-4306	7/22/2004	
TYPED OR PRINTED			AREA CODE	NUMBER	YR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITEE NAME/ADDRESS

NAME **James Canyon Well System**
 ADDRESS **P.O.Box 680**
Huntington, Utah 84528

FACILITY **James Canyon Well System**
 LOCATION **Huntington, Utah 84528**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

11T0025534
 PERMIT NUMBER

001 A
 DISCHARGE NUMBER

MINOR

F-FINAL
 JC-3 PUMPING PLATFORM TO LAKE

Form Approved
 OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 4	0 6	0 1	0 4	0 6	3 0

*** NO DISCHARGE ***

ATTN: Darce Guymon (PROJECT REPRESENTATIVE)

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMENT 45614 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** 0	*****	0	(94)	*****	*****	*****	*****		1/30	VISUAL
	PERMIT REQUIREMENT	*****	DAILY MX	YES = 1 NO = 0	*****	*****	*****	*****	*****	ONCE/MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** 373	*****	*****	*****	*****	*****	*****	(19)	1	2/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	DAILY MX	MG/L	*****	ONCE/MONTH	GRAB
MERCURY, DISSOLVED (AS HG) 71890 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** <0.02	*****	*****	*****	*****	<0.02	<0.02	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	*****	ONCE/MONTH	GRAB
MERCURY, TOTAL (AS HG) 71900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT ***** <0.02	*****	*****	*****	*****	<0.02	<0.02	(19)		1/30	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 30 DA AVG	REPORT DAILY MX	MG/L	*****	ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER
DAVE SHARP
 MANAGING DIRECTOR, PLANT
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.
 (Reference all attachments here)

Darce Guymon
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 435 687-4306
 DATE
 7/22/2004
 AREA CODE NUMBER YR MO DA

COMMENT AND EXPLANATION OF ANY VIOLATIONS