

0030

INTERNAL
0007005

From: Gregg Galecki
To: Pam Grubaugh-Littig; Susan White; Wayne Hedberg
Date: 8/4/2004 7:36:31 AM
Subject: JC-3 Update (Skyline well into Electric Lake)

FYI

JC-3 - The well completed within the mine workings is no longer in service. The DMR Pacificorp submitted to DWQ for June indicated they were out of compliance with exceeded limits on TDS (373; limit of 255) and Fe (0.94; limit 0.5). This includes blending with JC-1 water. Chris Hansen indicated the last time they checked JC-3 individually, TDS was ~700 mg/l. Also, a transformer is currently in need of repair @ JC-3.

This combined information suggests JC-3 will not be running anytime in the near future.

Gregg