

From: Gregg Galecki
To: C Hansen
Date: 4/12/04 1:53PM
Subject: PHC submittal

Chris,
You just knew there was going to be more..... Table PHC A-1 and Drawing PHC A-2 still don't match (3 times).

11 Left Headgate XC24 'current flow': table says 500 gpm; Drawing say 900 gpm

11 Left Headgate XC40 'current flow': table 700 gpm; Drawing 1000gpm

11 Left Set-up Room 'current flow': table 700 gpm; Drawing 1300 gpm

This is one item that Pcorp 'got me on' in the CHIA in the last round.

Gregg