

OGMCOAL - Skyline 3rd Quarter Water Monitoring

From: "Galecki, Gregg" <GGalecki@archcoal.com>
To: "OGMCOAL@utah.gov" <OGMCOAL@utah.gov>, Karl Houskeeper <karlhouskeeper@u...>
Date: 11/28/2011 7:04 AM
Subject: Skyline 3rd Quarter Water Monitoring
CC: "Belcher, Austin" <ABelcher2@archcoal.com>

All:

Water Monitoring data for the 3rd quarter 2011 for the Skyline Mine has been OK'd by the Mine and ready for uploading into the Master file. All the required data has been submitted with the following exceptions:

- All age-dating information still needs to be uploaded (has not been received from the lab)
- UPDES-001 is requesting T-Fe when it is not required; (a reoccurring problem) on 7/19, 8/2, 8/17, 8/30, 9/14, 9/27 (needs to be corrected by DOGM)
- CS-3; error on O&G – a separate O&G analysis will not load (needs to be corrected by DOGM)
- Well 92-91-03; (weird error) – "Program not recognizable" when I go to upload (needs to be corrected by DOGM)
- ELD-1; won't accept the JC-1 well is not pumping and out of service for August and September (needs to be corrected by DOGM)

Let me know if there are any questions,

Gregg A. Galecki
Environmental Engineer
Canyon Fuel Company, LLC
Skyline Mine
(435)448-2636

***Email Disclaimer: The information contained in this e-mail, and in any accompanying documents, may constitute confidential and/or legally privileged information. The information is intended only for use by the designated recipient. If you are not the intended recipient (or responsible for delivery of the message to the intended recipient), you are hereby notified that any dissemination, distribution, copying, or other use of, or taking of any action in reliance on this e-mail is strictly prohibited. If you have received this e-mail communication in error, please notify the sender immediately and delete the message from your system.