

August 10, 2015

Mr. Ken Hoffman  
Department of Environmental Quality  
Division of Water Quality  
P.O. Box 144870  
195 North 1950 West  
Salt Lake City, Utah 84114-4870

Subject: Permit exceedance for total Iron for the Canyon Fuel Company, LLC. Skyline Mine UPDES Permit UT0023540

Dear Mr. Hoffman:

Skyline Mine had an exceedance for total Iron on July 20<sup>th</sup>, 2015. In our regular weekly UPDES sampling (bi-weekly total Iron), we had a total Iron value of 1.46 mg/L. We received the lab report on August 10<sup>th</sup>. This is most likely due to a temporary change in our pumping system underground, which has since ended. We do not anticipate high iron readings in the future.

If you have any questions regarding this information, please give me a call at (435) 448-2662.

Sincerely:



Carl Winters  
Engineering Manager  
Canyon Fuel Company, LLC. - Skyline Mine  
[cwinters@bowieresources.com](mailto:cwinters@bowieresources.com)