

0069



KAISER COAL CORPORATION
Sunnyside Coal Mines
P.O. Box D
Sunnyside, Utah 84539
Telephone (801) 888-4421

July 2, 1985

RECEIVED

JUL 05 1985

DIVISION OF OIL
GAS & MINING

Mr. Dave Lof
Division of Oil, Gas & Mining
355 West North Temple
3 Triad Center, Suite 350
Salt Lake City, Utah 84180-1203

RE: NOV N85-4-17-3, 3 of 3
ACT/007/007, Sunnyside Mines

Dear Mr. Lof:

After your inspection on June 19, 1985 Mr. Scott Johnson of our staff called Mr. Joe Helfrich with a request that water in the pond be allowed to discharged with a pump to facilitate emergency repairs. After verbal approval from Mr. Helfrich a three H.P. pump was installed. During the installation Mr. D. Wayne Hedberg and Mr. Tom Suscouski inspected the site and saw no problem with the discharge plan.

On thursday June 20, 1985 during your next inspection you requested that samples be taken of the discharge water to insure compliance with water standards. This was done.


On friday June 21, 1985 Mr. Johnson called Mr. Helfrich requesting that emergency repairs be approved. The repairs were approved with the stipulation that: 1) an inspection of the emergency conditions be verified verbally and in writing from M.S.H.A., 2) repairs be completed before pumping starts, 3) that inspection of the structure be made daily for two weeks and 4) as built plans be submitted to the Division for approval.

Repairs to the discharge structure consisted of cementing the culvert joints both inside and outside of the pipe. The repairs took place on June 22 and 24, 1985.

After verifying approval to pump under emergency conditions the mine pump was started. Discharge from the culvert started July 1, 1985 at 9:00 AM. Examination of the embankment showed no seepage through the soil around the culvert. Monitoring will continue daily as requested.

A copy of the letter requesting that written verification the emergency conditions from M.S.H.A. is enclosed. Also enclosed are are as-built plans for the repairs that were made. These plans replace the previous plans submitted for this violation.

Sincerely yours,

A handwritten signature in cursive script that reads "Douglas C Pearce". The signature is written in dark ink and is positioned directly below the typed name.

Douglas C Pearce
Mine Engineer