



STATE OF UTAH
NATURAL RESOURCES & ENERGY
Oil, Gas & Mining

Scott M. Matheson, Governor
Temple A. Reynolds, Executive Director
Cleon B. Feight, Division Director

4241 State Office Building • Salt Lake City, UT 84114 • 801-533-5771

May 5, 1982

Mr. Glen Sides
U.S. Steel Corporation
P.O. Box 807
East Carbon, Utah 84520

RE: Raptor Survey
Wellington Prep Plant
ACT/007/012
Carbon County, Utah

Dear Mr. Sides:

As per your request, the USFWS has surveyed the powerlines at the Wellington Coal Preparation Plant.

After reviewing the results of the survey (enclosed) the Division feels that modifying existing poles would not be necessary at this time. However, we do want to point out that the configurations are potentially hazardous and should be altered as poles are replaced.

As per the Division's policy, modification of specified poles would be required should it become apparent that raptors are starting to use the power poles.

If you have any questions, please don't hesitate to call myself or Sue Linner.

Sincerely,

LYNN KUNZLER
RECLAMATION BIOLOGIST

Enclosure

cc: OSM, Albuquerque

LMK/cp