

0067



State of Utah

FILE COPY

DEPARTMENT OF ENVIRONMENTAL QUALITY DIVISION OF AIR QUALITY

Michael O. Leavitt
Governor

Dianne R. Nielson, Ph.D.
Executive Director

Russell A. Roberts
Director

150 North 1950 West
P.O. Box 144820
Salt Lake City, Utah 84114-4820
(801) 536-4000 Voice
(801) 536-4099 Fax
(801) 536-4414 T.D.D.

March 5, 1996

DAQH-249-96

Randy McClure
Rocmont Industrial Corporation
774 South 500 West
Salt Lake City, Utah 84101

RE: Approval of Variance for Remote Decontamination Unit at Wellington Wash Plant

Dear Mr. McClure:

Your request for a variance from R307-1-8.6.1.A.(4)(a) (worker decontamination system required) has been reviewed. Rocmont Industrial Corporation is approved to use a remote shower and decontamination unit at the Wellington Wash Plant project, provided the contaminated Tyvek suits are removed and left in the work area as described in your March 4, 1996 request for a variance. This variance is only applicable to the Wellington Wash Plant project. All other provisions of the Utah Air Conservation Rules apply to this project.

If you have any questions concerning this matter, please contact Larry Larkin at (801) 536-4085.

Sincerely,


Russell A. Roberts, Executive Secretary
Utah Air Quality Board

RAR:LPL:svw



FEB-14-96 WED 15:24

ROCMONT IND CORP

FAX NO. 801358-655

P.01

RECEIVED

DAQH-677-95

FEB 14 1996

my

UTAH DIVISION OF AIR QUALITY

REVISED NOTIFICATION of DEMOLITION or RENOVATION and ASBESTOS REMOVAL

Air Quality

OFFICE USE ONLY

Date Received: Postmark Date: Initials:

I. Type of Operation: [X] Demolition [] Ordered Demolition [] Renovation [] Ordered Renovation

II. ORIGINAL NOTIFICATION DATE: January 23, 1996 DAQH Approval #133-96

III. Facility Description: Please Complete Fully!

A. Building Name: Wellington Coal Wash Facility

B. Street Address:

C. City: Wellington

State: Utah

Zip:

IV. A. Asbestos Removal Contractor: Rocmont Industrial Corp. ID# 014

Contact Person: Randy P. McClure

Telephone #: 801-363-9941

B. Demolition Contractor (if applicable): Unknown

Contact Person:

Telephone #:

V. New Asbestos Removal Dates (Date ACM will be disturbed):

Start: March 5, 1996

Complete: March 22, 1996

A. Work Days (S M T W T F S)

B. Work Hours: 0700 to 1800

VI. New Dates of Demolition/Renovation: Start: Complete:

VII. ADDITIONAL Regulated Asbestos-Containing Material (RACM) to be Removed:

(Please include only additional material not included on original notification)

1. Pipes

2. Surface Area:

3. Vol. ACM off Facility Component:

(Linear Feet)

(Square Feet)

(Cubic Yards)

VIII. OTHER CHANGES OR COMMENTS TO ORIGINAL NOTIFICATION

McKay-Kim has been identified as the demolition contractor

IX. Date these changes were phoned to Division of Air Quality (536-4000):

Name of person contacted at DAQ: Bowen Call

X. I Certify that the Above Information is Correct.

[Signature] (Signature of Owner/Operator)

Feb. 14, 1996

(Date)

MAR- 4-96 MON 16:26

ROCMONT IND CORP

FAX NO. 8013557

RECEIVED

P. 01

3/4/96

1520 hrs

DAQH-677-95

MAR 04 1996

UTAH DIVISION OF AIR QUALITY

REVISED NOTIFICATION of DEMOLITION or RENOVATION and ASBESTOS REMOVAL

Air Quality

OFFICE USE ONLY

Date Received: Postmark Date: Initials:

I. Type of Operation: [X] Demolition [] Ordered Demolition [] Renovation [] Ordered Renovation

II. ORIGINAL NOTIFICATION DATE: January 23, 1996

DAQH Approval #133-96

III. Facility Description: Please Complete Fully!

A. Building Name: Wellington Wash Plant

B. Street Address:

C. City: Wellington

State: Utah

Zip:

IV. A. Asbestos Removal Contractor: Rocmont Industrial Corp.

ID# 014

Contact Person: Randy P. McClure

Telephone #: 801-563-9941

B. Demolition Contractor (if applicable): Unknown

Contact Person:

Telephone #:

V. New Asbestos Removal Dates (Date ACM will be disturbed):

Start: March 5, 1996

Complete: March 22, 1996

A. Work Days (S M T W T F S)

B. Work Hours: 0700 to 1800

VI. New Dates of Demolition/Renovation: Start:

Complete:

VII. ADDITIONAL Regulated Asbestos-Containing Material (RACM) to be Removed:

(Please include only additional material not included on original notification)

1. Pipes

2. Surface Area:

3. Vol. ACM off Facility Component:

(Linear Feet)

(Square Feet)

(Cubic Yards)

VIII OTHER CHANGES OR COMMENTS TO ORIGINAL NOTIFICATION

Since our original notification all plant utilities, except electricity, have been discontinued. There is currently no potable water on site. In order to construct and maintain a proper decontamination facility, Rocmont will utilize a remote decon unit located approximately 100 yards from a fully contained abatement area. Rocmont will supply water for this decon unit via 55 gallon barrels. Double Tyvek suits will be worn during abatement. Prior to exiting each worker will remove the outer Tyvek suit and will be HEPA vacuumed off. After being deemed debris free, workers will proceed directly to the remote decon unit for decontamination.

IX. Date these changes were phoned to Division of Air Quality (536-4000): March 4, 1996

Name of person contacted at DAQ: Larry Larkins

X. I Certify that the Above Information is Correct.

[Signature]

(Signature of Owner/Operator)

March 4, 1996

(Date)



State of Utah

FILE COPY

DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF AIR QUALITY

DAQH-133-96

Michael O. Lesvitt
Governor
Dianne R. Nielson, Ph.D.
Executive Director
Russell A. Roberts
Director

150 North 1950 West
P.O. Box 144820
Salt Lake City, Utah 84114-4820
(801) 536-4000 Voice
(801) 536-4099 Fax
(801) 536-4414 T.D.D.

ASBESTOS NOTIFICATION REVIEW

Asbestos Abatement Contractor:

Maureen H. Elliott
Rocmont Industrial Corporation
774 South 500 West
Salt Lake City, Utah 84101

Date Submitted: 1/23/96 Date Received: 1/23/96

Project Location: Wellington Wash Plant, Dryer Bldg., Wellington, Carbon County

Project Dates: Approved to begin disturbing Regulated Asbestos Containing Material 3/1/96 to 3/15/96

Reviewed By: Bowen Call Date Reviewed: 2/9/96

Follow-up / Comments:

- 1) 800 ln. ft. of asbestos-containing removed pipe insulation will be removed.
- 2) Asbestos waste material will be disposed of at the Waste Control Management landfill.
- 3) Rocmont Industrial Corporation will notify the Division of Air Quality if the actual dates of asbestos removal change from those listed above.

Recommendation:

The notification requirements of Subpart M have been met. This asbestos removal project notification is approved.

Date Approved: 2/9/96

Approved by:

Russell A. Roberts, Executive Secretary
Utah Air Quality Board

RAR:ABC:abc

cc: Southeastern Utah District Health Department
Utah OSHA, Bob Dreman

