

From: Neil Taylor
To: Paul Baker
Date: 12/1/97 8:15am
Subject: PCB Spill

0052

ACT 007/012

#5

DEQ INCIDENT NOTIFICATION
=====

INCIDENT: 92166 REPORTED TO: NEIL TAYLOR

REPORTING PARTY

NAME: JAY MARSHALL TITLE:
COMPANY: GENWAL COAL CO.
PHONE: (801)-637-0350 DATE REPORTED: 07/22/92 TIME: 12:05:00
INCIDENT DATE: 07/22/92 TIME: 07:30:00 ENDING DATE: TIME:

RESPONSIBLE PARTY

NAME/FIRM: GENWAL COAL CO.
ADDRESS: CASTLE VALLEY PLANT
TELEPHONE: (801)-637-0350

INCIDENT SUMMARY

TRANSFORMER LEAK
PCB CONTAMINATED OIL 8 - 10 GALLONS
SPILL DURING PCB REPLACEMENT
MATERIAL ENTIRELY CLEANED UP. CONCRETE REMOVED

ADDRESS/LOCATION: CASTLE VALLEY PLANT

NEAREST CITY: WELLINGTON COUNTY: CARBON
HIGHWAY: MILEMARKER:

IN/NEAR WATER: no WATERWAY NAME: NONE
FIRE?: no INJURIES?: No NUMBER: 0 FATALITIES: no NUMBER: 0

NATIONAL RESPONSE CENTER NOTIFIED(Y/N): yes NRC REPORT #: 128259

NOTIFICATIONS MADE FOR THIS INCIDENT

AGENCY:
PERSON:
DATE: TIME:

LEAD AGENCY & CONTACT: S&HW
PHONE NUMBER:

DERR ASSISTANCE PROVIDED FOR THIS INCIDENT

RESPONDERS: