


0010

BEAVER CREEK Coal Company
P. O. Box AU
Price, Utah 84501
Telephone 801 637-5050

FILE ACT/007/018



Copy to Gil &
Sally
JIM

July 28, 1981

JUL 31 1981

Mr. James W. Smith, Jr.
Coordinator, Mined Land Development
Division of Oil, Gas & Mining
Utah Department of Natural Resources
1588 West North Temple
Salt Lake City, Utah 84116

RECEIVED
JUL 30 1981

DIVISION OF
OIL, GAS & MINING

Re: Gordon Creek #2 Mine
Water System

Dear Mr. Smith:

Pursuant to our meeting with Sally Kefer on Tuesday, July 21, 1981, the following technical data on water usage at Gordon Creek #2 Mine is submitted:

Gordon Creek #2 Mine has a water usage factor of 3.2 gallon/ton. With three (3) units working (based on 700 ton/day/unit) the mine will use 6,720 gallons per day. This figure is substantially lower than the minimum water rights shown below and will be verified by installation of a water meter on the new line:

<u>User's Claim #</u>	<u>Period</u>	<u>Sec. Ft.</u>	<u>Gallon/Day</u>
91-353	May 1 to Sept 1	.015	9,694
91-94	Sept 1 to May 1	.150	96,941
91-330	Jan 1 to Dec 31	250 gpm	360,000

This additional data, along with the letter dated July 20, 1981, is a formal request for construction approval.

Sincerely,

Bert Jeanselme
Engineering

BJ/rh