0008

# Document Information Form

Mine Number: C/007/016

File Name: Internal

**To:** DOGM

**From:**

**Person** N/A

**Company** N/A

**Date Sent:** N/A

**Explanation:**

Discharge Monitoring Report

**cc:**

**File in:**
C/ 007 , 016 , Internal
**Refer to:**
- ☐ **Confidential**
- ☐ **Shelf**
- ☐ **Expandable**

Date _____ For additional information

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME BEAVER CREEK COAL

ADDRESS P.O. BOX 1375

PRICE UT 84501

FACILITY

LOCATION

ATTN: DAN W. GUY, MANAGER

J.C. #3 & #6

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

**DISCHARGE MONITORING REPORT (DMR)**

Route to Ken file

Form Approved. OMB No. 2040-0004. Approval expires 6-30-91.

| (2-16) PERMIT NUMBER | (17-19) DISCHARGE NUMBER |
|---|---|
| UTG040014 | 001 A |

MINOR ~~AC/007/017~~ #7

F - FINAL

OUTFALL

*** NO D ***

NOTE: Rem ting this form.

| MONITORING PERIOD | YEAR | MO | DAY | | YEAR | MO | DAY |
|---|---|---|---|---|---|---|---|
| FROM | 92 | 10 | 01 | TO | 92 | 12 | 31 |
| | (20-21) | (22-23) | (24-25) | | (26-27) | (28-29) | (30-31) |

File in: Confidential / Shift / Supplemental / DOG

Refer to Record No 0003 Date _____ Internal

In C/ 007 , 016 ,

For additional information

| PARAMETER (32-37) | | (3 Card Only) (46-53) QUANTITY OR LOADING (54-61) AVERAGE | MAXIMUM | UNITS | (4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) MINIMUM | AVERAGE | (54-61) MAXIMUM | | FREQUENCY OF ANALYSIS (64-68) | SAMPLE TYPE (69-70) |
|---|---|---|---|---|---|---|---|---|---|---|
| FLOW RATE 00056 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | | | ( 07) | ******* | ******* | *** | | | |
| | PERMIT REQUIREMENT | REPORT 30 DA AV | REPORT DAILY MX | GPD | ***** | ***** | **** | | /MONTH | GRAB |
| 00400 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | ******* | ( ) | | ******* | | | | |
| | PERMIT REQUIREMENT | ***** | ***** | *** **** | 6.5 DAILY MN | ***** | 9.0 DAILY | | ONCE/ MONTH | GRAB |
| SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | ******* | ( ) | ******* | | | | | |
| | PERMIT REQUIREMENT | ***** | ***** | *** **** | ***** | 35 30 DA AV | 70 DAILY MX | MG/L | /MONTH | GRAB |
| SOLIDS, SETTLEABLE 00545 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | ******* | ( ) | ******* | ******* | | ( 25) | | |
| | PERMIT REQUIREMENT | ***** | ***** | *** **** | ***** | ***** | 0.5 DAILY MX | ML/L | ONCE/ MONTH | GRAB |
| OIL AND GREASE FREON EXTR-GRAV METH 00556 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | ******* | ( ) | ******* | ******* | | ( 19) | | |
| | PERMIT REQUIREMENT | ***** | ***** | *** **** | ***** | ***** | 10 DAILY MX | MG/L | ONCE/ MONTH | GRAB |
| IRON, TOTAL (AS FE) 01045 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | ******* | ( ) | ******* | ******* | | ( 19) | | |
| | PERMIT REQUIREMENT | ***** | ***** | *** **** | ***** | ***** | 2.0 DAILY MX | MG/L | ONCE/ MONTH | GRAB |
| SOLIDS, TOTAL DISSOLVED 70295 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ******* | | ( 26) | ******* | ******* | | ( 19) | | |
| | PERMIT REQUIREMENT | ***** | 2000 DAILY MX | LBS/DY | ***** | ***** | REPORT DAILY MX | MG/L | ONCE/ MONTH | GRAB |

| NAME/TITLE PRINCIPAL EXECUTIVE OFFICER | | TELEPHONE | | DATE | | |
|---|---|---|---|---|---|---|
| Kathleen Welt<br>Environmental Supervisor | I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. *(Penalties under these statutes may include fines up to $10,000 and/or maximum imprisonment of between 6 months and 5 years.)* | SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT | 303 AREA CODE | 929 5015 NUMBER | 92 YEAR | 01 MO | 29 DAY |
| TYPED OR PRINTED | | | | | | |

COMMENT AND EXPLANATION OF ANY VIOLATIONS (*Reference all attachments here*)

TDS IS LIMITED TO ONE TON PER DAY FROM ALL OUTFALLS. DURING PRECIPITATION EVENTS SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS. REPORT "DOES NOT APPLY" IN APPROPRIATE ROW.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

J.C. #3 & #6

NAME SEAVER CREEK COAL

ADDRESS P.O. BOX 1378

PRICE UT 84501

FACILITY

LOCATION

ATTN: DAN W. GUY, MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
**DISCHARGE MONITORING REPORT (DMR)**

Route to Ken file #7

Form Approved. OMB No. 2040-0004. Approval expires 6-30-91.

| PERMIT NUMBER (2-16) | DISCHARGE NUMBER (17-19) |
|---|---|
| UT0040014 | 001 A |

MINOR ~~ACT~~ 007 1017

F - FINAL

OUTFALL FROM SED. POND

*** NO DISCHARGE [X] ***

| MONITORING PERIOD | YEAR | MO | DAY | | YEAR | MO | DAY |
|---|---|---|---|---|---|---|---|
| FROM | 92 | 10 | 01 | TO | 92 | 12 | 31 |
| | (20-21) | (22-23) | (24-25) | | (26-27) | (28-29) | (30-31) |

**NOTE: Read instructions before completing this form.**

| PARAMETER (32-37) | | (3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE | (54-61) MAXIMUM | UNITS | (4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM | (46-53) AVERAGE | (54-61) MAXIMUM | UNITS | NO. EX (62-63) | FREQUENCY OF ANALYSIS (64-68) | SAMPLE TYPE (69-70) |
|---|---|---|---|---|---|---|---|---|---|---|---|
| FLOW RATE 00056 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | | | (07) | ****** | ****** | ****** | ( ) | | | |
| | PERMIT REQUIREMENT | REPORT 30 DA AV | REPORT DAILY MX | GPD | ****** | ****** | ****** | *** **** | | ONCE/ MONTH | CALC |
| PH 00400 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | | ****** | | (12) | | | |
| | PERMIT REQUIREMENT | ****** | ****** | *** **** | 6.5 DAILY MN | ****** | 9.0 DAILY MX | SU | | ONCE/ MONTH | GRAB |
| SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | | | (19) | | | |
| | PERMIT REQUIREMENT | ****** | ****** | *** **** | ****** | 25 30 DA AV | 70 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| SOLIDS, SETTLEABLE 00545 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | (25) | | | |
| | PERMIT REQUIREMENT | ****** | ****** | *** **** | ****** | ****** | 0.5 DAILY MX | ML/L | | ONCE/ MONTH | GRAB |
| OIL AND GREASE FREON EXTR-GRAV METH 00556 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | (19) | | | |
| | PERMIT REQUIREMENT | ****** | ****** | *** **** | ****** | ****** | 10 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| IRON, TOTAL (AS FE) 01045 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | (19) | | | |
| | PERMIT REQUIREMENT | ****** | ****** | *** **** | ****** | ****** | 2.0 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| SOLIDS, TOTAL DISSOLVED 70295 1 0 0 EFFLUENT GROSS VALUE | SAMPLE MEASUREMENT | ****** | | (26) | ****** | ****** | | (19) | | | |
| | PERMIT REQUIREMENT | ****** | 2000 DAILY MX | LBS/DY | ****** | ****** | REPORT DAILY MX | MG/L | | ONCE/ MONTH | GRAB |

| NAME/TITLE PRINCIPAL EXECUTIVE OFFICER | | TELEPHONE | | DATE | | |
|---|---|---|---|---|---|---|
| Kathleen Welt<br>Environmental Supervisor | I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C § 1001 AND 33 U.S.C § 1319. *(Penalties under these statutes may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.)* | SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT | AREA CODE 303 | NUMBER 929 5015 | YEAR 92 | MO 01 | DAY 29 |
| TYPED OR PRINTED | | | | | | |

COMMENT AND EXPLANATION OF ANY VIOLATIONS (*Reference all attachments here*)

TDS IS LIMITED TO ONE TON PER DAY FROM ALL OUTFALLS. DURING PRECIPITATION EVENTS SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS. REPORT "DOES NOT APPLY" IN APPROPRIATE ROW.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME BEAVER CREEK COAL
ADDRESS P.O. BOX 1378
PRICE UT 84501

FACILITY
LOCATION
ATTN: DAN W. GUY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
**DISCHARGE MONITORING REPORT (DMR)**

(2-16) UTG040015 — PERMIT NUMBER
(17-19) 001 A — DISCHARGE NUMBER

MINOR
F - FINAL
WITHIN FOREST SVC BOUNDARY

Form Approved.
OMB No. 2040-0004.
Approval expires 6-30-91.

MONITORING PERIOD

| FROM YEAR | MO. | DAY | TO YEAR | MO. | DAY |
|---|---|---|---|---|---|
| 92 | 10 | 01 | 92 | 12 | 31 |
| (20-21) | (22-23) | (24-25) | (26-27) | (28-29) | (30-31) |

*** NO DISCHARGE |X| ***

**NOTE: Read instructions before completing this form.**

| PARAMETER (32-37) | | (3 Card Only) (46-53) QUANTITY OR LOADING (54-61) AVERAGE | MAXIMUM | UNITS | (4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) MINIMUM | AVERAGE | MAXIMUM | UNITS | NO. EX (62-63) | FREQUENCY OF ANALYSIS (64-68) | SAMPLE TYPE (69-70) |
|---|---|---|---|---|---|---|---|---|---|---|---|
| FLOW RATE | SAMPLE MEASUREMENT | | | ( 07) | ****** | ****** | ****** | ( ) | | | |
| 00056 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | REPORT 30 DA AV | REPORT DAILY MX | GPD | ****** | ****** | ****** | ***** | | ONCE/ MONTH | MEASRD |
| | SAMPLE MEASUREMENT | ****** | ****** | ( ) | | ****** | | ( 12) | | | |
| 00400 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | ****** | ***** | 6.5 DAILY MN | ****** | 9.0 DAILY MX | SU | | TWICE/ MONTH | GRAB |
| SOLIDS, TOTAL SUSPENDED | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | | | ( 19) | | | |
| 00530 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | ****** | ***** | ****** | 25 30 DA AV | 70 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| SOLIDS, SETTLEABLE | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | ( 25) | | | |
| 00545 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | ****** | ***** | ****** | ****** | 0.5 DAILY MX | ML/L | | ONCE/ MONTH | GRAB |
| OIL AND GREASE FREON EXTR-GRAV METH | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | ( 19) | | | |
| 00556 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | ****** | ***** | ****** | ****** | 10 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| IRON, TOTAL (AS FE) | SAMPLE MEASUREMENT | ****** | ****** | ( ) | ****** | ****** | | ( 19) | | | |
| 01045 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | ****** | ***** | ****** | ****** | 2.0 DAILY MX | MG/L | | ONCE/ MONTH | GRAB |
| SOLIDS, TOTAL DISSOLVED | SAMPLE MEASUREMENT | ****** | | ( 26) | ****** | ****** | | ( 19) | | | |
| 70295 1 0 0 EFFLUENT GROSS VALUE | PERMIT REQUIREMENT | ****** | 2000 DAILY MX | LBS/DY | ****** | ****** | REPORT DAILY MX | MG/L | | ONCE/ MONTH | GRAB |

| NAME/TITLE PRINCIPAL EXECUTIVE OFFICER | | TELEPHONE | | DATE | | |
|---|---|---|---|---|---|---|
| Kathleen Welt<br>Environmental Supervisor | I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. *(Penalties under these statutes may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.)* | SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT | 303 | 9295015 | 93 | 01 | 29 |
| TYPED OR PRINTED | | AREA CODE | NUMBER | YEAR | MO | DAY |

COMMENT AND EXPLANATION OF ANY VIOLATIONS (*Reference all attachments here*)

TDS IS LIMITED TO ONE TON PER DAY FROM ALL OUTFALLS. DURING PRECIPITATION EVENTS SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS. REPORT "DOES NOT APPLY" IN APPROPRIATE ROW.