

0029

Incoming
C 0070019
R

From: April Abate
To: Dave Shaver
CC: OGMCOAL@utah.gov
Date: 9/9/2009 1:20 PM
Subject: Re: Tower monitoring well #1
Place: OGMCOAL@utah.gov
Attachments: April Abate.vcf

Thank you, Dave. Glad to hear that it was a success!

April

April A. Abate
Environmental Scientist II
Division of Oil, Gas and Mining
1594 W. North Temple, Suite 1210
Salt Lake City, Utah 84114-5801
T: 801.538.5214
F: 801.359.3940
M: 801.232.1339

>>> "Shaver, Dave" <dshaver@coalsource.com> 9/9/2009 1:08 PM >>>

April and Karla...Scamp Excavation completed the installation of the new pump at water monitoring well #1 at Tower/Centennial yesterday (9/8/2009). They tested it out and it is working properly. The electricians added a new start/stop button, in addition to the breaker. Also, the flexible discharge pipe now extends out of the hole for about 30' which should make it easier to take the samples. Therefore, everything is now in place to resume the regular sampling program. Presently, the static water level is at depth 93', the pump is set at 113' and the bottom of the hole is at 122'. You will recall that several weeks ago we had a drilling company come in and totally clean out the well, so we should now be in good shape for a while.

Dave