

## OGMCOAL - Tower Well at the Centennial Mine

---

**From:** April Abate  
**To:** Dana Marrelli; OGMCOAL@utah.gov  
**Date:** 5/2/2011 7:22 AM  
**Subject:** Tower Well at the Centennial Mine  
**Attachments:** April Abate.vcf

---

Thanks for the update Dana. Just wondering if you were able to figure out why the pump went down in the first place. Was it clogged with sediment?

**April A. Abate**

*Environmental Scientist III*

Division of Oil, Gas and Mining  
1594 W. North Temple, Suite 1210  
Salt Lake City, Utah 84114-5801  
T: 801.538.5214  
M: 801.232.1339

>>> "Marrelli, Dana" <dmarrelli@coalsource.com> 4/29/2011 8:24 AM >>>

Good Morning April,

I wanted to give you an update on the Tower Well. On Thursday, April 28<sup>th</sup>, we put in a new pump at Tower. The old pump is being rebuilt and that will be our backup pump. The bottom of the well is 260' and the pump was placed at 190'. The water level was measured at 85'. The pump is working great and I did get my samples for 2<sup>nd</sup> quarter. Please let me know if you have any questions...

Thank you,

*Dana Marrelli*

Utah American Energy Inc.

PO Box 910

East Carbon, Utah 84520

Work: 435-888-4026

Cell: 435-650-9799