

0037

Hidden Splendor Resources
Horizon Mine
P.O. Box 32, Helper, Utah 84526
Phone: (435) 472-1313 – Fax: (435) 472-1314

INCOMING
00070020

October 6, 2003

Ms. Pamela Grubaugh-Littig
Utah Coal Program
Utah Division of Oil, Gas and Mining
1594 West North Temple – Suite 1210
Box 145801
Salt Lake City, UT 84114-5801

Dear Pam:

Hidden Splendor Resources respectfully submits the September 2003 – Discharge Monitoring Reports (DMRs) associated with the Horizon Mine UPDES Permit UTG040019. If you have any questions, please feel free to call me at 435-472-1313.

Sincerely,



Kit Pappas

OCT 08 2003

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LOBESTAR ENERGY, INC. - HORIZON**

ADDRESS **H C BOX 370
HELPER UT 84526**

FACILITY **LOBESTAR ENERGY, INC. - HORIZON**

LOCATION **HELPER UT 84526**

ATTN: **DAVID MILLEY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 001 A
PERMIT NUMBER DISCHARGE NUMBER

MINOR

F - FINAL
SEDIMENT POND OUTFALL

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
03	09	01	03	09	31

FROM TO

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		No DISCHARGE (07)									
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/MONTH	MEASRD
PH								(12)			
00400 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				6.5 MINIMUM		9.0 MAXIMUM	SD		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED								(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, SETTLEABLE								(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT						0.5 DAILY MX	ML/L		ONCE/MONTH	VISUAL
OIL & GREASE								(19)			
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						10 DAILY MX	MG/L		ONCE/MONTH	GRAB
IRON, TOTAL (AS FE)								(19)			
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						1.0 DAILY MX	MG/L		ONCE/MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL				(94)							
45613 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT		0 DAILY MX	YES=1 NO=0						ONCE/MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

KIT PAPPAS
TYPED OR PRINTED

435 492-1313 03 10 06
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 H¹ PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/ Location (if different))

NAME **LODESTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370 HELPER UT 84526**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

076040079 001 A
PERMIT NUMBER DISCHARGE NUMBER

MINOR

F - FINAL
SEDIMENT POND OUTFALL

FACILITY **LODESTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**
ATTN: **DAVID MILLER**

MONITORING PERIOD
YEAR MO DAY YEAR MO DAY
FROM 03 09 01 TO 03 09 31

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMENT 45614 1 0 0 EFFLUENT GROSS VALUE				(94)							
	PERMIT REQUIREMENT		DAILY MAX	YES=1 NO=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 R 0 0 SEE COMMENTS BELOW								(19)			
	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER KIT PAPPAS TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Kit Pappas</i>	TELEPHONE	DATE		
			435-472-1313 AREA CODE NUMBER	03	10	06 YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 IN PRECIPITATION EVENT. ENTER N.R. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTED IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME **LODESTAR ENERGY, INC. - HORIZON**

ADDRESS **H C BOX 370
HELPER UT 84526**

FACILITY **LODESTAR ENERGY, INC. - HORIZON**

LOCATION **HELPER UT 84526**

ATTN: **DAVID MILLER**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 **002 A**
PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD

FROM **03 09 01** TO **03 09 31**

MINOR

F - FINAL SRM
PIPE TO JEWKES CRK TO N F GORD

NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE				(07)							
00056 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	350									
	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/MONTH	MEASURED
PH											
00400 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT						8.40	(12)			
	PERMIT REQUIREMENT				6.5 MINIMUM		9.0 MAXIMUM	SO		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED											
00530 P 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT					<5		(19)			
	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, SETTLEABLE											
00545 Q 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT						0.5	(25)			
	PERMIT REQUIREMENT						DAILY MX	ML/L		ONCE/MONTH	GRAB
OIL & GREASE											
00556 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT						<2	(19)			
	PERMIT REQUIREMENT						10	DAILY MX		ONCE/MONTH	GRAB
IRON, TOTAL (AS FE)											
01045 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT						0.107	(19)			
	PERMIT REQUIREMENT						1.0	DAILY MX		ONCE/MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL											
45613 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT		0	(94)							
	PERMIT REQUIREMENT		0	YES=1 NO=0						ONCE/MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

KET PAPPAS
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435 472 1313**
DATE **03 10 06**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/ Location if Different)
NAME LODESTAR ENERGY, INC. - HORIZON
ADDRESS M C BOX 370
 HELPER UT 84526
FACILITY LODESTAR ENERGY, INC. - HORIZON
LOCATION HELPER UT 84526
ATTN: DAVID MILLER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

UTG040019 002 A
 PERMIT NUMBER DISCHARGE NUMBER

MINOR
 F - FINAL SRM
 PIPE TO JEWES CRK TO N F GORD

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
03	09	01	TO	03	09	31

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMEN 45614 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	*****	0	(94)	*****	*****	*****				
	PERMIT REQUIREMENT	*****	DAILY MX	YES=1 NO=0	*****	*****	*****	****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 R 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****		*****	466	*****	(19)			
	PERMIT REQUIREMENT	*****	*****	*** ***	*****	REPORT 30DA AVG	*****	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER KIT PAPPAS TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>KIT PAPPAS</i>	TELEPHONE	DATE		
			435 472-1313 AREA CODE NUMBER	03	10	06 YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTED IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 1020
HUNTINGTON, UT 84528
TEL: (435) 653-2311
FAX: (435) 653-2436

October 2, 2003

HIDDEN SPLENDOR RESOURCES INC.
57 WEST 200 SOUTH, SUITE 400
SALT LAKE CITY UT. 84101
DAVID MILLER

Sample identification by
HIDDEN SPLENDOR RESOURCES

ID: updes-002

Kind of sample Water
reported to us

RECEIVED 1515

SAMPLED 1400

FIELD MEASUREMENTS

FLOW 350 TEMP 16
COND. 670 pH 8.40

Sample taken at HORIZON MINE

Sample taken by K.P.

NOTES:

Date sampled September 23, 2003

Date received September 23, 2003

Page 1 of 1

Analysis report no. 59-25709

Parameter	Result	MRL	Units	Method	Analyzed		
					Date/Time	Analyst	
Iron, Total	0.107	0.02	mg/l	EPA 200.7	10-01-2003	1115	DI
Oil & Grease	<2	2	mg/l	EPA 413.1	09-24-2003	0800	DI
Solids, Total Dissolved	466	30	mg/l	EPA 160.1	09-25-2003	0800	JJ
Solids, Total Suspended	<5	5	mg/l	EPA 160.2	09-25-2003	0800	JJ

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Huntington Laboratory

MEMBER
ACIL

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-485
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE