

0040

INCOMING
00070020
Email Dana D.

Hidden Splendor Resources
Horizon Mine
P.O. Box 32, Helper, Utah 84526
Phone: (435) 472-1313 – Fax: (435) 472-1314

December 1, 2003

Ms. Pamela Grubaugh-Littig
Utah Coal Program
Utah Division of Oil, Gas and Mining
1594 West North Temple – Suite 1210
Box 145801
Salt Lake City, UT 84114-5801

Dear Pam:

Hidden Splendor Resources respectfully submits the November 2003 – Discharge Monitoring Reports (DMRs) associated with the Horizon Mine UPDES Permit UTG040019. If you have any questions, please feel free to call me at 435-472-1313.

Sincerely,



Kit Pappas

RECEIVED
DEC 03 2003
DIV. OF OIL, GAS & MINING

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME **LOBSTAR ENERGY, INC. - HORIZON**

ADDRESS **H C BOX 370
HELPER UT 84526**

FACILITY **LOBSTAR ENERGY, INC. - HORIZON**

LOCATION **HELPER UT 84526**

ATTN: **DAVID MILLER**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

HTG040019
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MINOR

F - FINAL
SEDIMENT POND OUTFALL

MONITORING PERIOD

FROM **03 11 01** TO **03 11 03**

~~NO DISCHARGE~~

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		No DISCHARGE									
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT	REPORT	(01)						ONCE/	WEASRD
		30DA AVG	DAILY MX	GPD						MONTH	
PH	SAMPLE MEASUREMENT							(12)			
00400 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				6.5		9.0			ONCE/	GRAB
					MINIMUM		MAXIMUM	30		MONTH	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT							(19)			
00530 1 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25	35	70			ONCE/	GRAB
					30DA AVG	MX 7D AV	DAILY MX	MG/L		MONTH	
SOLIDS, SETTLEABLES	SAMPLE MEASUREMENT							(25)			
00545 0 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT						0.5			ONCE/	VISUAL
							DAILY MX	ML/L		MONTH	
OIL & GREASE	SAMPLE MEASUREMENT							(19)			
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						10			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT							(19)			
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						1.0			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
FLOATING SOLIDS OR VISIBLES (UAG-VISUAL)	SAMPLE MEASUREMENT			(94)							
03613 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT									ONCE/	VISUAL
										MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

KIT PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-1313**
DATE **03 12 1**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SET FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME **LODESTAR ENERGY, INC. - HORIZON**

ADDRESS **H C BOX 370
HELPER UT 84526**

FACILITY **LODESTAR ENERGY, INC. - HORIZON**

LOCATION **HELPER UT 84526**

ATTN: **DAVID MILLER**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

076040019
PERMIT NUMBER

007 A
DISCHARGE NUMBER

MINOR

F - FINAL
SEDIMENT POND OUTFALL

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
03	11	01	TO	03	11	30

NO DISCHARGE []

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Sanitary Waste Discharged - Assessment 45014 1 0 0 Effluent Gross Value	SAMPLE MEASUREMENT			(94)							
	PERMIT REQUIREMENT		DAILY MAX	YES=1 NO=0						ONCE/MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 R 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT							(19)			
	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435 472-1313**
DATE **03 12 1**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
NAME LODUSTAN ENERGY, INC. - HORIZON
ADDRESS R C BOX 370
 HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

UTG040019
PERMIT NUMBER
 002 A
DISCHARGE NUMBER

MINOR
 F - FINAL
 PIPE TO JFWRES CRK TO N F GORD SRM

FACILITY LODUSTAN ENERGY, INC. - HORIZON
LOCATION HELPER UT 84526
ATTN: DAVID MILLER

MONITORING PERIOD
 FROM 03 11 01 TO 03 11 31

NO DISCHARGE YES
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE			350	(07) GPM							
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/ MONTH	MEASRD
PH						8.20	(12)				
00490 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				6.5 MINIMUM	9.0 MAXIMUM	50			ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED						<5	(19)				
00530 2 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE							(25)				
00545 3 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT					0.5 DAILY MX	ML/L			ONCE/ MONTH	GRAB
OIL & GREASE						<2	(19)				
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT					10 DAILY MX	MG/L			ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)						0.098	(19)				
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT					1.0 DAILY MX	MG/L			ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL			0	(94)							
45613 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT		0 DAILY MX	YES=1 NO=0						ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER KET PAPPAS / ENV. COORD TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<i>Ket Pappas</i> SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			435	472-1313	03	12	01

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUP FROM ALL CUTEALLS.
 This is a 4-part form. PAGE 1 OF 1
 00193/03 11 01

PERMITTEE NAME/ADDRESS (Include Facility Name/ Location (if Different))

NAME **LOBESTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370**
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 002
PERMIT NUMBER DISCHARGE NUMBER

MINOR

F - FINAL SRM
PIPE TO JEWKES CRK TO N F GORD

FACILITY **LOBESTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
03	11	01		03	11	3

NO DISCHARGE
NOTE: Read instructions before completing this form.

ATTN: DAVID MILLER

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSM 45614 1 0 0 EFFLUENT GROSS VALU			0	(94)							
	PERMIT REQUIREMENT		DAILY MAX	RES=1 WC=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 8 0 0 SEE COMMENTS BELOW						417		(19)			
	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

KIT PAPPAS/Env. Coord.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

KIT PAPPAS
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE *435 432-1313*
DATE *03 12 01*
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 1020
HUNTINGTON, UT 84528
TEL: (435) 653-2311
FAX: (435) 653-2436
www.camteco.com

November 24, 2003

HIDDEN SPLENDOR RESOURCES INC.
57 WEST 200 SOUTH, SUITE 400
SALT LAKE CITY UT. 84101
DAVID MILLER

Sample identification by
HIDDEN SPLENDOR RESOURCES

ID: updes-002

Kind of sample Water
reported to us

RECEIVED 1340
SAMPLED 1300

Sample taken at HORIZON MINE

FIELD MEASUREMENTS
FLOW 350 TEMP 14
COND. 650 pH 8.20

Sample taken by KP

NOTES:

Date sampled November 11, 2003

Date received November 11, 2003

Page 1 of 1

Analysis report no. 59-25916

Parameter	Result	MRL	Units	Method	Analyzed		
					Date/Time/Analyst		
Iron, Total	0.098	0.02	mg/l	EPA 200.7	11-19-2003	2215	DI
Oil & Grease	<2	2	mg/l	EPA 413.1	11-12-2003	0900	BLP
Solids, Total Dissolved	417	30	mg/l	EPA 160.1	11-13-2003	0800	DI
Solids, Total Suspended	<5	5	mg/l	EPA 160.2	11-13-2003	0800	DI

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Huntington Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

F-465
Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE