

0001

Hidden Splendor Resources
Horizon Mine
P.O. Box 32, Helper, Utah 84526
Phone: (435) 472-1313 – Fax: (435) 472-1314

J. Pappas
1/007/0020
E-mail Dana D.

January 2, 2004

Ms. Pamela Grubaugh-Littig
Utah Coal Program
Utah Division of Oil, Gas and Mining
1594 West North Temple – Suite 1210
Box 145801
Salt Lake City, UT 84114-5801

Dear Pam:

Hidden Splendor Resources respectfully submits the December 2003 – Discharge Monitoring Reports (DMRs) associated with the Horizon Mine UPDES Permit UTG040019. If you have any questions, please feel free to call me at 435-472-1313.

Sincerely,



Kit Pappas

RECEIVED
JAN 06 2004
DIV. OF OIL, GAS & MINING

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LODESTAR ENERGY, INC. - HORIZON**

ADDRESS **4 C BOX 370
HOLPER UT 84526**

FACILITY **LODESTAR ENERGY, INC. - HORIZON**

LOCATION **HOLPER UT 84526**

ATTN: **DAVID MILLER**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

07E040019
PERMIT NUMBER

001
DISCHARGE NUMBER

MINOR

F - FINAL
SEDIMENT POND OUTFALL

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
03	12	01	03	12	31

FROM TO

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		No DISCHARGE									
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT	REPORT	(01)						ONCE/	WEASRD
		30DA AVG	DAILY MX	GPD						MONTH	
00400 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT							(12)			
	PERMIT REQUIREMENT				6.5		9.0			ONCE/	GRAB
					MINIMUM		MAXIMUM	SU		MONTH	
00530 2 0 0 SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT							(19)			
	PERMIT REQUIREMENT				25	35	70			ONCE/	GRAB
					30DA AVG	MX 7D AV	DAILY MX	MG/L		MONTH	
00545 2 0 0 SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT							(25)			
	PERMIT REQUIREMENT						0.5			ONCE/	VISUAL
							DAILY MX	ML/L		MONTH	
00556 1 0 0 OIL & GREASE EFFLUENT GROSS VALU	SAMPLE MEASUREMENT							(19)			
	PERMIT REQUIREMENT						10			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
01045 1 0 0 IRON, TOTAL (AS FE) EFFLUENT GROSS VALU	SAMPLE MEASUREMENT							(19)			
	PERMIT REQUIREMENT						1.0			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
45513 1 0 0 FLOATING SOLIDS OR VISIBLE FOAM-VISUAL EFFLUENT GROSS VALU	SAMPLE MEASUREMENT			(94)							
	PERMIT REQUIREMENT			0 YES=1 DAILY MX NO=0						ONCE/	VISUAL
										MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KET PAPPAS/ENV. COORDINATOR
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-1313**
DATE **04 01 02**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

NAME **LODESTAR ENERGY, INC. - HORIZON**
 ADDRESS **500 BOX 370**
HELPER OH 44526

DTG040019 **001**
PERMIT NUMBER **DISCHARGE NUMBER**

81808

F - FINAL
SEDIMENT POND OUTFALL

FACILITY **LODESTAR ENERGY, INC. - HORIZON**
 LOCATION **HELPER OH 44526**

MONITORING PERIOD
 FROM **03 12 01** TO **03 1 31**

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED - 45614 1-0-0	PERMIT REQUIREMENT		0	MG=1						ONCE/MONTH	VISUAL
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		DAILY MAX	NO=0							
SOLIDS, TOTAL DISSOLVED	PERMIT REQUIREMENT					REPORT				ONCE/MONTH	GRAB
70295 8-0-0	PERMIT REQUIREMENT					30DA AVG		MG/L			
SEE COMMENTS BELOW	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KET PAPPAS / ENV. COORDINATOR
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435 492-1313**
 DATE **04 01 02**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MINOR

NAME **LODSTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370 HELPER UT 84526**
FACILITY **LODSTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**
ATTN: **DAVID MILLER**

UTG040019
PERMIT NUMBER

002 A
DISCHARGE NUMBER

F - FINAL
PIPE TO JEWERS CRK TO N F GORD

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
03	12	01	03	12	31

*** NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE			350	(07) GPM							
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/ MONTH	MEASHD
PH						8.00	(12)				
00400 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				6.5 MINIMUM	9.0 MAXIMUM	SU			ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED						13	(19)				
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D A	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE							(25)				
00545 0 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT					0.5 DAILY MX	ML/L			ONCE/ MONTH	GRAB
OIL & GREASE						<2.0	(19)				
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT					10 DAILY MX	MG/L			ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)						0.972	(19)				
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT					1.0 DAILY MX	MG/L			ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL			0	(94)							
45613 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT		0 DAILY MX	YES=1 NO=0						ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORDINATOR
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
435 492-1313

DATE
04 01 02

AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL CUTEALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MINOR

NAME **LODESTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370**
HELPER UT 84526

016040019
PERMIT NUMBER

002
DISCHARGE NUMBER

F - FINAL SRM
PIPE TO JERRIES CRK TO N F GORD

FACILITY **LODESTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
03	12	01	TO	03	12	31

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMENT 45614 I U O EFFLUENT CROSS VALU			0	(94)							
	PERMIT REQUIREMENT		DAILY MAX	YES=1 NO=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 R U U SEE COMMENTS BELOW						313		(19)			
	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORDINATOR
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-1313**
DATE **04 01 02**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THIS PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®



Member of the SGS Group (Société Générale de Surveillance)

Committed To Excellence

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 1020
HUNTINGTON, UT 84528
TEL: (435) 653-2311
FAX: (435) 653-2436
www.comteco.com

December 23, 2003

HIDDEN SPLENDOR RESOURCES INC.
57 WEST 200 SOUTH, SUITE 400
SALT LAKE CITY UT. 84101
DAVID MILLER

Sample identification by
HIDDEN SPLENDOR RESOURCES

ID:UPDES-002A

Kind of sample reported to us Water

RECEIVED 1340
SAMPLED 1100

FIELD MEASUREMENTS

Sample taken at HORIZON MINE

FLOW 350 TEMP 13
COND. 570 pH 8.00

Sample taken by KP

NOTES:

Date sampled December 10, 2003

Date received December 10, 2003

Page 1 of 1

Analysis report no. 59-26026

Parameter	Result	MRL	Units	Method	Analyzed		
					Date/Time/Analyst		
Iron, Total	0.972	0.02	mg/l	EPA 200.7	12-22-2003 1000	BLP	
Oil & Grease	<2	2	mg/l	EPA 413.1	12-17-2003 0830	JJ	
Solids, Total Dissolved	313	30	mg/l	EPA 160.1	12-11-2003 0800	JJ	
Solids, Total Suspended	13	5	mg/l	EPA 160.2	12-11-2003 0800	JJ	

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Huntington Laboratory



OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS, TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES