

0027

Hidden Splendor Resources
Horizon Mine
P.O. Box 32, Helper, Utah 84526
Phone: (435) 472-1313 – Fax: (435) 472-1314

August 9, 2004

Ms. Pamela Grubaugh-Littig
Utah Coal Program
Utah Division of Oil, Gas and Mining
1594 West North Temple – Suite 1210
Box 145801
Salt Lake City, UT 84114-5801

Incoming
8/007/0020

Dear Pam:

Hidden Splendor Resources respectfully submits the July 2004 – Discharge Monitoring Reports (DMRs) associated with the Horizon Mine UPDES Permit UTG040019.

If you have any questions, please feel free to call me at 435-472-0431.

Sincerely,



Kit Pappas
Engineering/Environmental

RECEIVED

AUG 12 2004

DIV. OF OIL, GAS & MINING

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LODESTAR ENERGY, INC. - HORIZON**

ADDRESS **8 C BOX 310
HELPER UT 84526**

FACILITY **LODESTAR ENERGY, INC. - HORIZON**

LOCATION **HELPER UT 84526**

ATTN: **DAVID MILLER**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

DTG040019 **001 A**
PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
04	07	01		04	07	31

MIROR

P - FINAL
SEDIMENT POND OUTFALL

NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		No Discharge			(07)						
00056 1 0 0 EFFLUENT GROSS VALUE		REPORT	REPORT							ONCE/	MEASURED
30DA AVG		DAILY MX		GPD						MONTH	
PH								(12)			
00400 1 0 0 EFFLUENT GROSS VALUE					6.5		9.0			ONCE/	GRAB
30DA AVG					MINIMUM		MAXIMUM			MONTH	
SOLIDS, TOTAL SUSPENDED								(19)			
00530 2 0 0 50% COMMENTS BELOW					25	35	70			ONCE/	GRAB
30DA AVG					MG/L		DAILY MX			MONTH	
SOLIDS, SETTLEABLE								(25)			
00545 0 0 0 50% COMMENTS BELOW							0.5			ONCE/	VISUAL
DAILY MX							ML/L			MONTH	
OIL & GREASE								(19)			
00556 1 0 0 EFFLUENT GROSS VALUE							10			ONCE/	GRAB
DAILY MX							MG/L			MONTH	
IRON, TOTAL (AS FE)								(19)			
01045 1 0 0 EFFLUENT GROSS VALUE							1.0			ONCE/	GRAB
DAILY MX							MG/L			MONTH	
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL								(94)			
45613 1 0 0 EFFLUENT GROSS VALUE					0	YES=1				ONCE/	VISUAL
DAILY MX					NO=0					MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435 492-0431**
DATE **07 08 09**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLES SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME **LODESTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370**
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UT0040019 PERMIT NUMBER
001 A DISCHARGE NUMBER

MINOR

P - FINAL
SEDIMENT POND OUTFALL

FACILITY **LODESTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**

MONITORING PERIOD

FROM **04 07 01** TO **04 07 31**

~~NO DISCHARGE~~ ***
NOTE: Read instructions before completing this form.

ATTN: DAVID GILLER

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMAN				(94)							
45614 1 0 0			0	PERMS=1						ONCE/	VISUAL
EFFLUENT GROSS VALU			DAILY AX	NG=0						MONTH	
SOLIDS, TOTAL DISSOLVED								(19)			
70295 R 0 0						REPORT				ONCE/	GRAB
SEE COMMENTS BELOW						30DA AVG		MG/L		MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KET PAPPAS / ENV. COORD.
TYPED/OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Ket Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-0431**
DATE **04 08 09**

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SEPTICABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 NG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTED IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SET FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LODENTAS ENERGY, INC. - HORIZON**
ADDRESS **P.O. BOX 370**
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 **002 A**
PERMIT NUMBER DISCHARGE NUMBER

MINOR

F - FINAL **SRM**
PIPE TO JEWKES CRK TO N F GORD

FACILITY **LODENTAS ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**
ATTN: **DAVID WILLET**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
04	07	01	TO	04	07	31

NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		350		(07) CPM							
00036 1 0 0 EFFLUENT GROSS VALU		REPORT	REPORT							ONCE/	MEASRD
		30DA AVG	DAILY MX	GPD						MONTH	
PH							8.10	(12)			
00400 1 0 0 EFFLUENT GROSS VALU					6.5		9.0			ONCE/	GRAB
					MINIMUM		MAXIMUM	SD		MONTH	
SOLIDS, TOTAL SUSPENDED							< 5	(19)			
00530 2 0 0 SEE COMMENTS BELOW					25	25	70			ONCE/	GRAB
					30DA AVG	EX 7D AV	DAILY MX	MG/L		MONTH	
SOLIDS, SETTLEABLE								(25)			
00545 0 0 0 SEE COMMENTS BELOW							0.5			ONCE/	GRAB
							DAILY MX	ML/L		MONTH	
OIL & GREASE							< 2	(19)			
00556 1 0 0 EFFLUENT GROSS VALU							10			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
IRON, TOTAL (AS FE)							0.05	(19)			
01045 1 0 0 EFFLUENT GROSS VALU							1.0			ONCE/	GRAB
							DAILY MX	MG/L		MONTH	
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL			0	(94)							
45513 1 0 0 EFFLUENT GROSS VALU			0	YES=1						ONCE/	VISUAL
			DAILY MX	NO=0						MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-0431**
DATE **04 08 09**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED BY EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME **LOBSTAR ENERGY, INC. - HORIZON**
ADDRESS **H C BOX 370**
HELPSR UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

DTG040019
PERMIT NUMBER
002
DISCHARGE NUMBER

MINOR
F - FINAL
PIPE TO JEWKES CRK TO N F GORD
SRM

FACILITY **LOBSTAR ENERGY, INC. - HORIZON**
LOCATION **HELPSR UT 84526**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
04	07	01		04	07	31

FROM 04 07 01 TO 04 07 31

NO DISCHARGE []
NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SEWAGE TREATMENT PLANT DISCHARGE - ASSESSED			0	(94)							
45614 1 0 0 EFFLUENT GROSS VALUE			DAILY MAX	#C=0						ONCE/MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED						425		(19)			
70295 2 0 0 SEE COMMENTS BELOW						REPORT 30DA AVG				ONCE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KET PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

TELEPHONE
435492-0431

DATE
04 08 09

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Ket Pappas

AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SHOWN FROM ALL OUTFALLS.

SGS

August 5, 2004

HIDDEN SPLENDOR RESOURCES INC.
57 WEST 200 SOUTH, SUITE 400
SALT LAKE CITY UT. 84101
Kit Pappas

Sample identification by
HIDDEN SPLENDOR RESOURCES

ID:UPDES-002A

Kind of sample Water
reported to us

RECEIVED 1315
SAMPLED 0900

Sample taken at HORIZON MINE

FIELD MEASUREMENTS
FLOW 350 TEMP 15
COND. 690 pH 8.10

Sample taken by K.P.

NOTES:

Date sampled July 26, 2004

Date received July 26, 2004

Page 1 of 1

Analysis report no. 59-26645

Parameter	Result	MRL	Units	Method	Analyzed		
					Date/Time	Analyst	
Iron, Total	0.05	0.050	mg/l	EPA 200.7	07-28-2004	1259	JJ
Oil & Grease	<2	2	mg/l	EPA 413.1	08-04-2004	0830	DI
Solids, Total Dissolved	425	30	mg/l	EPA 160.1	07-27-2004	0830	DI
Solids, Total Suspended	<5	5	mg/l	EPA 160.2	07-27-2004	0830	DI

MEMBER
ACIL

Respectfully submitted,
SGS NORTH AMERICA INC.

Huntington Laboratory

Minerals Services Division
P.O. Box 1020, Huntington, UT 84528 t(435) 853-2311 f(435) 653-2436 www.sgs.com