

0032

INCOMING
00070020

**Hidden Splendor Resources
Mid State Services
Horizon Mine
P.O. Box 32, Helper, Utah 84526
Phone: (435) 472-0431 – Fax: (435) 472-0439**

September 2, 2004

Ms. Pamela Grubaugh-Littig
Utah Coal Program
Utah Division of Oil, Gas and Mining
1594 West North Temple – Suite 1210
Box 145801
Salt Lake City, UT 84114-5801

RECEIVED
SEP 13 2004
DIV. OF OIL, GAS & MINING

Dear Pam:

Hidden Splendor Resources respectfully submits the August 2004 – Discharge Monitoring Reports (DMRs) associated with the Horizon Mine UPDES Permit UTG040019.

If you have any questions, please feel free to call me at 435-472-0431.

Sincerely,



Kit Pappas
Engineering/Environmental

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LOUKSTAR ENERGY, INC. - HORIZON**
ADDRESS **8 C BOX 370**
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

DTG040019
PERMIT NUMBER
0014
DISCHARGE NUMBER

MINOR

FINAL
SEDIMENT POND OUTFALL

FACILITY **LOUKSTAR ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**

MONITORING PERIOD
FROM 04 01 01 TO 04 01 31

ATTN: DAVID MILLER

NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE		No Discharge (07)									
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	SPD						ONCE/MONTH	HEASRD
pH							(12)				
00400 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				6.5 MINIMUM		9.0 MAXIMUM	SD		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED							(19)				
00530 2 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D	70 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, SETTLEABLE							(25)				
00545 0 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT						0.5 DAILY MX	ML/L		ONCE/MONTH	VISUAL
OIL & GREASE							(19)				
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						10 DAILY MX	MG/L		ONCE/MONTH	GRAB
IRON, TOTAL (AS FE)							(19)				
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						1.0 DAILY MX	MG/L		ONCE/MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL				(94)							
45613 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT		0 YES=1 DAILY MX	NO=0						ONCE/MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kit Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435-472-0431**
DATE **04 09 02**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N/A WHEN NOT APPLICABLE. IF 30 DAY AVG TSS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTED IS LIMITED TO ONE TON (2000 LBS) PER DAY IS SUM FOR ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/ Location (if different))

NAME LODGESTAR ENERGY, INC. - HORIZON

ADDRESS H C BOX 370
HELPER UT 84525

FACILITY LODGESTAR ENERGY, INC. - HORIZON

LOCATION HELPER UT 84525

ATTN: DAVID MILLER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 PERMIT NUMBER 001 8 DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
04	08	01	TO	04	08	31

SEWAGE

F - FINAL
SEDIMENT POND OUTFALL

NO DISCHARGE ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGED-ASSESSMENT 45614 1 0 0 EFFLUENT GROSS VALUE				(94)							
	PERMIT REQUIREMENT			NEG=1 DAILY EX NO=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 8 0 0 SEE COMMENTS BELOW								(19)			
	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

KET PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kevin Pappas
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE 435 492-0431
DATE 04 09 02
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location (if Different))

NAME **LUDWIG ENERGY, INC. - HORIZON**
ADDRESS **100 BOX 370**
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

076040019 PERMIT NUMBER 002 A DISCHARGE NUMBER

MINOR
P - FINAL SRM
PIPE TO JEWKES CRK TO N F GORD

FACILITY **LUDWIG ENERGY, INC. - HORIZON**
LOCATION **HELPER UT 84526**
ATTN: **DAVID BILLEN**

MONITORING PERIOD
FROM 04 08 01 TO 04 08 31

NO DISCHARGE [] ***
NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	350 gpm			(07)							
00056 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/MONTH	MEASD
PH	8.10						(12)				
00090 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT				5.5 MINIMUM		9.0 MAXIMUM	SU		ONCE/MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	< 5						(19)				
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				25 30DA AVG	35 MX 7D	70 DAILY MX	MG/L		ONCE/MONTH	GRAB
SOLIDS, SETTLABLE	0.5						(25)				
00545 0 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT						0.5 DAILY MX	ML/L		ONCE/MONTH	GRAB
OIL & GREASE	< 2						(19)				
00556 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						10 DAILY MX	MG/L		ONCE/MONTH	GRAB
IRON, TOTAL (AS FE)	< 0.05						(19)				
01045 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT						1.0 DAILY MX	MG/L		ONCE/MONTH	GRAB
FLOCCING SOLIDS OR VISIBLY FLOATING SOLIDS	0			(94)							
45013 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT			YES=1 NO=0						ONCE/MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
KIT PAPPAS/ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

[Signature]
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **435 472-0431**
DATE **04 09 02**
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TSS OF 500 MG/L CANNOT BE ACHIEVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SOL FROM ALL CUTFALLS.

PERMITTEE NAME/ADDRESS (Include Facility Name/ Location (if Different))

NAME LODI STAR ENERGY, INC. - HORIZON
ADDRESS 4 C BOX 370
HELPER UT 84526

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

UTG040019 002 A
PERMIT NUMBER DISCHARGE NUMBER

WINGR

P - FINAL SRM
PIPE TO JEWKES CRK TO N F GORD

FACILITY LODI STAR ENERGY, INC. - HORIZON
LOCATION HELPER UT 84526

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
04	08	01	04	08	31

FROM TO

NO DISCHARGE
NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SANITARY WASTE DISCHARGE - ASSESSOR 45014 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT		0	(94)							
	PERMIT REQUIREMENT		0 DAILY MAX	YES=1 NO=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 8 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT					419	(19)				
	PERMIT REQUIREMENT					REPORT 30DA AVG	MG/L			ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

KEI PAPPAS / ENV. COORD.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

KEI PAPPAS

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

435 472-0431
AREA CODE NUMBER

DATE

04 09 02
YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SETTLABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A. WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHIEVED AT HIGH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

SGS

August 26, 2004

HIDDEN SPLENDOR RESOURCES INC.
57 WEST 200 SOUTH, SUITE 400
SALT LAKE CITY UT. 84101
Kit Pappas

Sample identification by
HIDDEN SPLENDOR RESOURCES

ID:UPDES-002A

Kind of sample Water
reported to us

RECEIVED 1200
SAMPLED 1000

Sample taken at HORIZON MINE

FIELD MEASUREMENTS
FLOW 350 TEMP 15
COND. 640 pH 8.1

Sample taken by K.P.

NOTES:

Date sampled August 22, 2004

Date received August 23, 2004

Page 1 of 1

Analysis report no. 59-26729

Parameter	Result	MRL	Units	Method	Analyzed	
					Date/Time	Analyst
Iron, Total	<0.05	0.050	mg/l	EPA 200.7	08-25-2004 1846	JJ
Oil & Grease	<2	2	mg/l	EPA 413.1	08-25-2004 0900	DI
Solids, Total Dissolved	419	30	mg/l	EPA 160.1	08-24-2004 0830	DI
Solids, Total Suspended	<5	5	mg/l	EPA 160.2	08-24-2004 0830	DI

MEMBER
ACIL

Respectfully submitted,
SGS NORTH AMERICA INC.



Huntington Laboratory

SGS North America Inc. Minerals Services Division
P.O. Box 1020, Huntington, UT 84528 t (435) 653-2311 f (435) 653-2436 www.sgs.com