



355 W. North Temple • 3 Triad Center • Suite 350 • Salt Lake City, UT 84180-1203 • 801-538-5340

November 10, 1987

TO: John Whitehead, Permit Supervisor
FROM: James R. Fricke, Reclamation Hydrologist *JRF*
RE: Culvert Amendment, Beaver Creek Coal Company, C. V. Spur
Loadout Facility, ACT/007/022-87E, Folder #2, Carbon
County, Utah

Synopsis

The operator has submitted an amendment (10/21/87) in the form of a Ten Day Notice (TDN) response (#8) for culvert installations.

Analysis:

- TDN #8 (a) The culvert numbers must be identified in the TDN response.
- (b)(1) Culvert C-13 is adequate to pass the design event.
(2) The two ten-inch culverts must be identified in the TDN response.
(3) Culvert C-2 is adequate to pass the design event.
- (c) The operator must provide the complete rip-rap plan for Culvert C-5. A filter blanket must be provided under all rip-rap installations.

Recommendation

The Division should not approve the amendment until the operator has corrected the discrepancies in (a), (b)(2), and (c).

jr
0798R/24