0003

Post-it® Fax Note 7671	Date 2/10/02 # of pages ▶ 2
To Greg Galecki	From Dan Guy
Co./Dept.	Co.
Phone #	Phone # (435) 637-2422
Fax # (801) 538-3940	Fax # (435) 637-2431

ok

Savage Industries Inc.
2025 East 5000 South
Price, Utah 84501

(435) 637-5664
(435) 637-3418 Fax

October 28, 2001

Mr. Donald A Hilden, PH.D., Chief
Permits and Compliance Section
Department of Environmental Quality
Division of Water Quality
288 North 1460 West
P.O. Box 144870
Salt Lake City, Utah 84114-4870

Incoming
C/007/022
WQ01-3

Dear Mr. Hilden:

Enclosed please find the Discharge Monitoring Report for Savage Industries, Inc. UPDES Permit Number UTG040005. This report covers the month of September 2001.

If you have any questions or need any additional information, please contact me.

Respectfully,

Dan W. Guy for
Boyd Rhodes,
Manager

Enclosures

DWG/ds

cc: Pamela Grubaugh-Littig, UDOGM
Dan Guy, Blackhawk Engineering, Inc.
File

C/ Corr 1022 - WQ01-3 Sept.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
NAME SAVAGE INDUSTRIES, INC.
ADDRESS C/O BLACKHAWK ENGINEERING
RT 1 BOX 146-H5
HELPER UT 84525
FACILITY SAVAGE COAL TERMINAL
LOCATION
ATTN: BOYD RHODES

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16) UTG040005 PERMIT NUMBER
(17-19) 001 A DISCHARGE NUMBER

MINOR
F - FINAL
SED PND OT FL DRNG DTCH/PRC RVR

Form Approved.
OMB No. 2040-0004
Approval expires 10-31-92

MONITORING PERIOD

	YEAR	MO	DAY		YEAR	MO	DAY
FROM	01	09	01	TO	01	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [X] ***
NOTE: Read Instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 DAILY MN	******	9.0 DAILY MX	SU		TWICE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******		******			(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	25 30DA AVG	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 R 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL AND GREASE FREON EXTR-GRAV METH	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******		(26)	******	******		(19)			
70295 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	2000 DAILY MX	LBS/DY	******	******	REPORT DAILY MX	MG/L		ONCE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BOYD RHODES
MANAGER
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
AREA CODE	NUMBER	YEAR	MO	DAY
435	637-2422	01	10	28

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

TDS IS LIMITED TO ONE TON PER DAY FROM ALL OUTFALLS. DURING PRECIPITATION EVENTS, SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS. REPORT "DOES NOT APPLY" IN THE APPROPRIATE ROW.

02/11/02 MON 12:12 FAX 435 637 2431 Blackhawk Engineering 002