

**SUNNYSIDE COGENERATION ASSOCIATES**POST OFFICE BOX 58087  
SALT LAKE CITY, UTAH 84158-0087

December 14, 1993

Randy Harden  
Division of Oil, Gas and Mining  
3 Triad Center, Suite 350  
Salt Lake City, Utah 84180-1203

RECEIVED

DEC 16 1993

DIVISION OF  
OIL, GAS & MININGRE: Sunnyside Cogeneration Associates (SCA) Permit No. ACT/007/035  
Project Number EC450593  
Violation N93-32-8-1

Dear Randy:

This letter is written in regards to Violation No. N93-32-8-1 received at Eckhoff Watson & Preator Engineering office on December 10, 1993.

"Failure to meet all Utah and Federal water quality standards and effluent limitations as described in UPDES Permit No. UT 0024759. Discharge Point #004 (i.e. Clear Water Pond) TSS exceedance of the Daily Maximum Limit of 70 mg/l."

SCA requests abatement of this violation as of December 14, 1993. There is currently no discharge at UPDES station 004. We are therefore in compliance with the permit conditions.

SCA's complete plan for continued compliance is outlined as follows:

1. Install filter fabric on the filter dike of Slurry Pond 2
2. Close valves to shut off discharge from Slurry Ponds 1 & 2 into Clear Water Pond
3. Pump water from the Clear Water Pond into Slurry Pond 1 or 2
4. Clean out coal fines from Clear Water Pond - to be placed in approved storage areas
5. Install filter fabric on the discharge pipe from Clear Water Pond
6. Clean out Slurry Pond 1 after sufficient drying time
7. Improve filter dike of Slurry Pond 1 prior to refilling with slurry


We believe that these steps will provide adequate long term compliance with the UPDES discharge limits for station 004, and we have already begun implementing the plan. Step 1 was completed on December 10, 1993. Step 2 was completed on December 10, 1993. Step 3 was completed on December 13, 1993.

Mr. Randy Harden  
December 14, 1993  
Page Two


---

Therefore, since there is currently no discharge from the Clear Water Pond, and future discharge is expected to meet all Utah and Federal water quality standards and effluent limitations as described in UPDES Permit No. UT 0024759, SCA requests abatement of Violation N93-32-8-1 as of December 14, 1993.

Sincerely,



David R Pearce  
Authorized Member, Management Committee



Alane E. Boyd, PE  
Senior Engineer  
Eckhoff, Watson and Preator Engineering

cc: Brian Burnett, CDN  
Joe Helfrich, DOGM