



State of Utah

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF OIL, GAS AND MINING

Michael O. Leavitt
Governor

Ted Stewart
Executive Director

James W. Carter
Division Director

355 West North Temple
3 Triad Center, Suite 350
Salt Lake City, Utah 84180-1203
801-538-5340
801-359-3940 (Fax)
801-538-5319 (TDD)

June 7, 1993

TO: Pamela Grubaugh-Littig, Permit Supervisor

FROM: Jess Kelley, Reclamation Engineer *JK*

RE: Field Verification of As-Built Drawing of Access Road, Sunnyside Cogeneration Associates, Sunnyside Cogeneration Facility, ACT/007/035, Folder #2, Carbon County, Utah

SYNOPSIS

On May 24, 1993, the permittee submitted, for Division approval, an as-built drawing of the access road and adjacent facilities at this site. This access road is a loop road which carries coal refuse to a truck dump conveyor which supplies the Sunnyside Cogeneration Associates (SCA) power plant. Also included in the drawing are the Pasture Sediment Pond and the topsoil stockpile which contains the topsoil removed for the placement of the access road. The drawing is designated 'Sheet Number 5-3 *Access Road Record Drawing.*'

ANALYSIS

I visited the site on May 28, 1993 for the purpose of field verifying the drawing of the access road. I paced the larger lateral dimensions of the road, the Pasture Sediment Pond, and the topsoil stockpile, measured the smaller dimensions with a tape, checked the locations and dimensions of culverts and ditches and the locations of the various features relative to one another, and checked the road surface material. I found all features to be in accordance with sound engineering practice and with the submitted drawing.

RECOMMENDATIONS

It is recommended that the access road drawing be approved and included as part of the approved plan.

SCAROAD.MEM

