0031

PLATEAU MINING CORPORATION
Willow Creek Mine
P.O. Box 30
Helper, Utah 84526
(435)472-0475
Fax: (435)472-4782

July 19, 2004

INCOMING
CORRESP

Mr. Michael Herkimer
State of Utah
Department of Environmental Quality
Division of Water Quality
P.O. Box 144870
Salt Lake City, Utah 84114-4870

Re: UPDES Report, June 2004 - Permit No. UTG040012

Dear Mr. Herkimer:

Discharge Monitoring Reports are enclosed. The potential to discharge from the permitted outfalls 002, 012, 013, 014 and 015 no longer exist. The sedimentation ponds have been removed as part of the Willow Creek Mine's reclamation in accordance with Utah's R645 Coal Rules. Outfall 011 has been partially backfilled. If you have any questions, please do not hesitate to contact me at (435) 472-4741.

Sincerely,

Johnny Pappas
Sr. Environmental Engineer

Enclosures

cc: UDOGM

File: Env: 2.5.2.1.2.1
Chrono: JP040701.ltr

RECEIVED
JUL 22 2004
DIV. OF OIL, GAS & MINING

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	SUM A

MINOR
F - FINAL
SUM OF ALL OUTFALLS

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| ***

NOTE: Read Instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
SOLIDS, TOTAL DISSOLVED /0295 Q 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	******		(26)	******	******	******				
	PERMIT REQUIREMENT	******	2000 DAILY MX	LBS/DY	******	******	******	**** ****		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER			TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	435 472-4741		04	07	19
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

IF TDS IS 500 MG/L OR LESS AT EACH OUTFALL ENTER N.A. FOR SUM A.

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	001 A

MINOR
F - FINAL
WILLOW CREEK DISCHARGE

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASUR
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 MINIMUM	******	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 70 AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45813 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Johnny Pappas
Sr. Env. Engineer
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE AREA CODE	NUMBER	DATE YEAR	MO	DAY
435	472-4741	04	07	19

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00087/030/02-1009 PAGE 1 OF

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	001 A

MINOR
F - FINAL
WILLOW CREEK DISCHARGE

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******	******		******		******	(19)			
70295 R 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	REPORT 30DA AVG	******	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Johnny Pappas
Sr. Env. Engineer
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE AREA CODE	NUMBER	DATE YEAR	MO	DAY
435	472-4741	04	07	19

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00088/030/02-1009 PAGE 2 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	002 A

MINOR
F - FINAL
WILLOW CREEK DISCHARGE

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| *** Backfilled

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 MINIMUM	******	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00207/030102 PAGE 1 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	002 A

MINOR
F - FINAL
WILLOW CREEK DISCHARGE

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| *** Backfilled

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMENT	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******	******		******		******	(19)			
70295 R 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	REPORT 30DA AVG	******	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00208/030102 PAGE 2 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	011 A

MINOR
F - FINAL
DISCHARGE TO PRICE RIVER

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| *** Backfilled

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 MINIMUM	******	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00327/030/02-1009 PAGE 1 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	011 A

MINOR
F - FINAL
DISCHARGE TO PRICE RIVER

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

*** NO DISCHARGE |X| *** Backfilled

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******	******		******		******	(19)			
70295 R 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	REPORT 30DA AVG	******	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00328/030/02-1009 PAGE 2 OF

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

UTG040012 — PERMIT NUMBER
012 A — DISCHARGE NUMBER

MINOR
F - FINAL
DISCHARGE TO PRICE RIVER

MONITORING PERIOD
FROM YEAR 04 MO 06 DAY 01 TO YEAR 04 MO 06 DAY 30

*** NO DISCHARGE [X] *** Backfilled

NOTE: Read Instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 MINIMUM	******	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. PAGE 1 OF 00447/030/02-1009

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

UTG040012 — PERMIT NUMBER
012 A — DISCHARGE NUMBER

MINOR
F - FINAL
DISCHARGE TO PRICE RIVER

MONITORING PERIOD
FROM YEAR 04 MO 06 DAY 01 TO YEAR 04 MO 06 DAY 30

*** NO DISCHARGE [X] *** Backfilled

NOTE: Read Instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******	******		******		******	(19)			
70295 M 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	REPORT 30DA AVG	******	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. PAGE 2 OF 00448/030/02-1009

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

UTG040012 — PERMIT NUMBER
013 A — DISCHARGE NUMBER

MONITORING PERIOD
FROM YEAR 04 MO 06 DAY 01 TO YEAR 04 MO 06 DAY 30

MINOR
F - FINAL
SED POND DSCHARGE TO PRICE RIV
*** NO DISCHARGE [X] Reclaimed ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	*****	*****	*****				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	*****	*****	*****	*** ***		ONCE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	*****	*****			*****		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*** ***	6.5 MINIMUM	*****	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*** ***	25 30DA AVG	35 MX 70 AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****		*****	*****		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*** ***	*****	*****	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*** ***	*****	*****	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*** ***	*****	*****	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	*****		(94)	*****	*****	*****				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	0 DAILY MX	YES=1 NO=0	*****	*****	*****	*** ***		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. PAGE 1 OF 1
00567/030/02-1009

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

UTG040012 — PERMIT NUMBER
013 A — DISCHARGE NUMBER

MONITORING PERIOD
FROM YEAR 04 MO 06 DAY 01 TO YEAR 04 MO 06 DAY 30

MINOR
F - FINAL
SED POND DSCHARGE TO PRICE RIV
*** NO DISCHARGE [X] Reclaimed ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT	*****		(94)	*****	*****	*****				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	0 DAILY MX	YES=1 NO=0	*****	*****	*****	*** ***		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	*****	*****		*****		*****	(19)			
70295 8 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*** ***	*****	REPORT 30DA AVG	*****	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. PAGE 2 OF 2
00568/030/02-1009

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

UTG040012 — PERMIT NUMBER
014 A — DISCHARGE NUMBER

MINOR
F - FINAL
SED POND TO CRANDALL CANYON

MONITORING PERIOD FROM 04 06 01 TO 04 06 30

*** NO DISCHARGE |X| ***

Reclaimed

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	MEASRE
PH	SAMPLE MEASUREMENT	******	******			******		(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 MINIMUM	******	9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	******	******					(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	******	******		******	******		(25)			
00545 Q 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	******	******		******	******		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER			TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	435	472-4741	04	07	19
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED ON ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00687/030702-1009 PAGE 1 OF

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

UTG040012 — PERMIT NUMBER
014 A — DISCHARGE NUMBER

MINOR
F - FINAL
SED POND TO CRANDALL CANYON

MONITORING PERIOD FROM 04 06 01 TO 04 06 30

*** NO DISCHARGE |X| ***

Reclaimed

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0 DAILY MX	YES=1 NO=0	******	******	******	**** ****		ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	******	******		******		******	(19)			
70295 R 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	REPORT 30DA AVG	******	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER			TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	435	472-4741	04	07	19
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED ON ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00688/030702-1009 PAGE 2 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	015 A

MINOR
F - FINAL
SED POND TO CRANDALL CANYON

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

NO DISCHARGE [X] Reclaimed

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT			(07)							
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	GPD						ONCE/ MONTH	MEASURE
PH	SAMPLE MEASUREMENT							(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT				6.5 MINIMUM		9.0 MAXIMUM	SU		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT							(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT				15 30DA AVG	35 MX 70 AV	70 DAILY MX	MG/L		ONCE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT							(25)			
00545 0 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT						0.5 DAILY MX	ML/L		ONCE/ MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT							(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT						10 DAILY MX	MG/L		ONCE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT							(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT						1.0 DAILY MX	MG/L		ONCE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT			(94)							
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		0 DAILY MX	YES=1 NO=0						ONCE/ MONTH	VISUAL

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00807/030702-2009 PAGE 1 OF

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*
NAME PLATEAU MINING CORP
ADDRESS WILLOW CREEK MINE
P.O. BOX 30
HELPER UT 84526
FACILITY PLATEAU MINING CORP
LOCATION HELPER UT 84526
ATTN: JOHNNY PAPPAS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

Form Approved.
OMB No. 2040-0004
Supersede C/007/0038

PERMIT NUMBER	DISCHARGE NUMBER
UTG040012	015 A

MINOR
F - FINAL
SED POND TO CRANDALL CANYON

MONITORING PERIOD	YEAR	MO	DAY		YEAR	MO	DAY
FROM	04	06	01	TO	04	06	30

NO DISCHARGE [X] Reclaimed

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
SANITARY WASTE DISCHARGED-ASSESSMNT	SAMPLE MEASUREMENT			(94)							
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		0 DAILY MX	YES=1 NO=0						ONCE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT							(19)			
70295 K 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT					REPORT 30DA AVG		MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		TELEPHONE		DATE		
Johnny Pappas Sr. Env. Engineer	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	435	472-4741	04	07	19
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
SETTLEABLE SOLIDS SHALL BE LIMITED INSTEAD OF TSS DURING RUNOFF EVENTS CAUSED BY LESS THAN THE 10 YR/24 HR PRECIPITATION EVENT. ENTER N.A.WHEN NOT APPLICABLE. IF 30 DAY AVG TDS OF 500 MG/L CANNOT BE ACHEIVED AT EACH OUTFALL, THEN PERMITTEE IS LIMITED TO ONE TON (2000 LBS) PER DAY AS SUM FROM ALL OUTFALLS.

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used. This is a 4-part form. 00808/030702-2009 PAGE 2 OF