

0017

Utah!

Where ideas connect

Department of Environmental Quality
Division of Water Quality

Michael O. Leavitt
Governor

Dianne R. Nielson, Ph.D.
Executive Director

Don A. Ostler, P.E.
Director

288 North 1460 West
P.O. Box 144870
Salt Lake City, Utah 84114-4870
(801) 538-6146
(801) 538-6016 Fax
(801) 536-4414 T.D.D.
www.deq.utah.gov

Water Quality Board
William R. Williams
Acting Chair
Robert G. Adams
Ray M. Child, C.P.A.
David F. Echols
Neil K. Kochenour, M.D.
Dianne R. Nielson, Ph.D.
Jay Ivan Olsen
Joseph Piccolo, Mayor
Ronald C. Sims, Ph.D.
Douglas E. Thompson, Mayor
J. Ann Wechsler
Don A. Ostler, P.E.
Executive Secretary

June 20, 2003

Mr. Randy J. Scott, Manager
Sunnyside Cogeneration Associates
P.O. Box 10
East Carbon, UT 85520

INCOMING
007 0042
COPY (0070035

Dear Mr. Scott:

Subject: Reconnaissance Inspections at Sunnyside Cogeneration Associates UT0024759 and Star Point Refuse Pile UTG040025.

On May 21st a Reconnaissance Inspection was completed at Sunnyside Cogeneration Associates (SCA). Based upon observations during the inspection it appears that the ponds associated with outfalls 015 and 017 needs to be cleaned and the outfall structure on 017 need repair. Would you please let us know when you plan on cleaning the ponds and fixing the outfall structure. As an observation, the coal refuse toe pond associated with outfall 012, was dry but the sediment on the bottom was a reddish color. All ponds appeared ready to function properly if needed with the exception of 017.

On May 27th I completed a Reconnaissance Inspection of the Star Point Refuse Pile. Outfalls 005, 006 and 009 were observed and no deficiencies or any other types of problems were noted. Therefore, no response regarding the Star Point Refuse Pile is required.

If you have any questions or concerns please contact me at (801) 538-6058 or mherkimer@utah.gov.

Sincerely,



Michael Herkimer, Environmental Scientist
Permitting & Compliance Section

Enclosures

cc: Darcy O'Connor, EPA Region VIII (w/encl)
Claron Bjork, Southeastern Utah Health Dist.
David Ariotti, Southeastern Regional Engineer (w/encl)
Pam Grubaugh-Littig, Division of Oil, Gas & Mining (w/encl)

U:\WQP\PERMITS\MHERKIME\wp\SCA ReconInsp5-21-03Ltr.doc

RECEIVED

JUN 30 2003

DIV. OF OIL, GAS & MINING

