



STATE OF UTAH  
NATURAL RESOURCES  
Oil, Gas & Mining

ACT/015/009 #2  
Norman H. Bangerter, Governor  
Dee C. Hansen, Executive Director  
Dianne R. Nielson, Ph.D., Division Director

355 W. North Temple • 3 Triad Center • Suite 350 • Salt Lake City, UT 84180-1203 • 801-538-5340

July 23, 1987

TO: John Whitehead, Permit Supervisor

FROM: James R. Fricke, Reclamation Hydrologist *JRF*

RE: Culinary Water Well Amendment, Arch of Utah, Trail Mountain Coal Company, Trail Mountain Mine, ACT/015/009, -87A, Folder No. 2, Emery County, Utah

The operator has submitted design plans to construct a culinary water well at the Trail Mountain mine site.

The plans are generally acceptable, although some modifications should be completed before the Division grants approval.

1. Upon completion of the water well, the operator must amend pertinent portions of the MRP.
  - A. The surety bond should be adjusted to reflect final abandonment costs.
  - B. The well should be located on the Surface Facilities map.
  - C. The ground-water section of the MRP must reflect the additional water well and should include final abandonment procedures.
2. The operator intends to install an access port in the well casing to acquire water level measurements. A water level conduit should be installed with the submersible pump to prevent interference with the water level measuring device and the pump pipe and electrical cable.
3. An as-built schematic of the well, pump installation, and a copy of the drillers report should be submitted upon completion of the well.

djh  
0798R/51