



# State of Utah

DEPARTMENT OF NATURAL RESOURCES  
DIVISION OF OIL, GAS AND MINING

Michael O. Leavitt  
Governor

Ted Stewart  
Executive Director

James W. Carter  
Division Director

355 West North Temple  
3 Triad Center, Suite 350  
Salt Lake City, Utah 84180-1203  
801-538-5340  
801-359-3940 (Fax)  
801-538-5319 (TDD)

May 17, 1993

TO: Pamela Grubaugh-Littig, Permit Supervisor

FROM: Jess Kelley, Reclamation Engineer *JK*

RE: Amendment to Allow for Construction of Concrete Loading Dock,  
PacifiCorp, Trail Mountain Mine, ACT/015/009-93D, Folder #2, Emery  
County, Utah

## SYNOPSIS

The permittee proposes to build a concrete loading dock at the Trail Mountain minesite. The loading dock will allow for greater efficiency and safety in loading and unloading supplies which are transported to and from the minesite by truck.

## ANALYSIS

The loading dock will be located in the main storage yard just south of the office/shop complex and adjacent to the storage shed which was built in May of this year (Amendment 93C). This area drains to the main sediment pond and the dock will have no effect on surface drainage. The dock has been added to the Surface Facilities Map, seven (7) copies of which will be sent to the Division when construction of the dock is complete.

The loading dock will be a simple reinforced concrete embankment structure. The platform will be 8 inches thick and approximately 14 feet long by 12 feet wide. The front will be 12 inches thick and approximately 12 feet wide by 42 inches high, while the back will, of course, be level with the storage yard surface. Side wing walls will be 42 inches high and approximately 6 feet long, as required by the slope against which the dock will be built. The permittee has included a design drawing of the storage dock with the present submittal.



Page 2  
Amendment Memo  
ACT/015/009-93D  
May 17, 1993

The permittee estimates the cost of removing the dock to be about \$410. This cost has been added to the overall reclamation cost estimate. The present reclamation bond is more than adequate to cover this additional reclamation cost.

### RECOMMENDATIONS

It is recommended that this amendment be approved and that construction of the loading dock be allowed to begin.

TMLDK.MEM