



State of Utah
DEPARTMENT OF NATURAL RESOURCES
DIVISION OF OIL, GAS AND MINING

1594 West North Temple, Suite 1210
PO Box 145801
Salt Lake City, Utah 84114-5801
(801) 538-5340 telephone
(801) 359-3940 fax
(801) 538-7223 TTY
www.nr.utah.gov

Michael O. Leavitt
Governor
Robert L. Morgan
Executive Director
Lowell P. Braxton
Division Director

November 15, 2002

TO: Internal Files

FROM: Stephen J. Demczak, Sr. Reclamation Specialist/Engineering, Team Lead *SJD bryan*

RE: Transmission Line, Consolidation Coal Company, Emery Deep Mine, C/015/015-02D-2

SUMMARY:

The permittee has submitted an amendment to construct a power line from the existing substation to the 4th East portals. The total length of the transmission line is 1.4 miles. The permittee will install approximately 38 power poles. The total disturbance will be 0.002 acres. No road will be used to service the power lines.

The permittee plans to construct the power lines once approval is given.

TECHNICAL ANALYSIS:

ENVIRONMENTAL RESOURCE INFORMATION

HISTORIC AND ARCHEOLOGICAL RESOURCE INFORMATION

Regulatory Reference: 30 CFR 783.12; R645-301-411.

Analysis:

The Division had determined that the proposed road linking County Road #907 to County Road #915, and the 4th East portals needed another historical and archeological study, since this power line is near or adjacent to the new purposed road and enters into the 4th East Portal facilities. The permittee has conducted an archeological survey along the power line corridor. Montgomery Archeological Consultants conducted the survey in August of 2002. One site was identified as historically significant and was marked in the field. This area will be avoided for the installation of the power poles.

TECHNICAL MEMO

Findings:

The information provided is considered adequate and met the minimum requirements of this section

FISH AND WILDLIFE RESOURCE INFORMATION

Regulatory Reference: 30 CFR 784.21; R645-301-322.

Analysis:

The Division had determined that the proposed road linking County Road #907 to County Road #915, and the 4th East portals needed an updated study of endangered or threatened species of plants and animals, since this power line is near or adjacent to the new proposed road and enters into the 4th East Portal facilities. The permittee has conducted a threatened and endangered plants survey by Larry England along the power line corridor. He found no individuals or suitable habitat of federally listed threatened and endangered species.

The permittee has submitted a raptor-protect design for the power poles. This design is on Plate IX-4 in this amendment. This design is P.E. certified.

The permittee will avoid wetlands or riparian vegetation.

Findings:

The information provided is considered adequate and meets the R645 Coal Rules of this section.

SOILS RESOURCE INFORMATION

Regulatory Reference: 30 CFR 783.21; 30 CFR 817.22; 30 CFR 817.200(c); 30 CFR 823; R645-301-220; R645-301-411.

Analysis:

No topsoil will be saved since the disturbance is small, less than 0.002 acres. Each power pole installation will cause one square foot of disturbance.

Findings:

The permittee has met the minimum requirements of this section.

MAPS, PLANS, AND CROSS SECTIONS OF RESOURCE INFORMATION

Regulatory Reference: 30 CFR 783.24, 783.25; R645-301-323, -301-411, -301-521, -301-622, -301-722, -301-731.

Analysis:

Permit Area Boundary Maps

The permittee has stated in the text that the power line is within the permit area.

Findings:

The permittee has met the minimum requirements of this section

OPERATION PLAN

FISH AND WILDLIFE INFORMATION

Regulatory Reference: 30 CFR Sec. 784.21, 817.97; R645-301-322, -301-333, -301-342, -301-358.

Analysis:

Protection and Enhancement

The proposed power pole configuration uses fiberglass triangular raptor protection devices and Kaddus bird guards in areas where 60 inches couldn't be achieved. It is determined to meet the minimum requirements to protect raptors.

Findings:

Information provided in the application is considered adequate to meet the minimum Fish and Wildlife Information requirements of the regulations.

TOPSOIL AND SUBSOIL

Regulatory Reference: 30 CFR Sec. 817.22; R645-301-230.

Analysis:

TECHNICAL MEMO

Removal and Storage

The permittee will not store or save the topsoil, because the disturbance of the power pole will be less than one square-foot. The total disturbance of 38 power poles will be 0.002 acres. In the event that more topsoil or vegetation is disturbed, the permittee will reclaim the disturbance as specified in Chapter VIII.C.4 in the MRP.

Findings:

The permittee has met the minimum requirements of this section.

VEGETATION

Regulatory Reference: R645-301-330, -301-331, -301-332.

Analysis:

The permittee will be disturbing 0.002 acres in the installation of a power line from the existing sub-station to the 4th East portals. This minor disturbance will not affect the vegetation in this area. In the event that more topsoil or vegetation is disturbed, the permittee will reclaim the disturbance as specified in Chapter VIII.C.4 in the MRP.

Findings:

The permittee has met the minimum requirements of this section.

HYDROLOGIC INFORMATION

Regulatory Reference: 30 CFR Sec. 773.17, 774.13, 784.14, 784.16, 784.29, 817.41, 817.42, 817.43, 817.45, 817.49, 817.56, 817.57; R645-300-140, -300-141, -300-142, -300-143, -300-144, -300-145, -300-146, -300-147, -300-147, -300-148, -301-512, -301-514, -301-521, -301-531, -301-532, -301-533, -301-536, -301-542, -301-720, -301-731, -301-732, -301-733, -301-742, -301-743, -301-750, -301-761, -301-764.

Analysis:

Exemptions for siltation structures

There will be no sediment control for the power line, since the total disturbance is less than one square-foot for each power pole. This would have no impact to the receiving waters.

Findings:

The permittee has met the minimum requirements of this section.

SUPPORT FACILITIES AND UTILITY INSTALLATIONS

Regulatory Reference: 30 CFR Sec. 784.30, 817.180, 817.181; R645-301-526.

Analysis:

The permittee has submitted an amendment to construct a power line from the existing sub-station to the 4th east portals. The length of the power line will be approximately 1.4 miles. It will consist of 38 power poles. This is indicated on Plate 11-3 of this amendment. This plate is P.E. certified.

Findings:

The permittee has met the minimum requirements of this section.

RECLAMATION PLAN

GENERAL REQUIREMENTS

Regulatory Reference: PL 95-87 Sec. 515 and 516; 30 CFR Sec. 784.13, 784.14, 784.15, 784.16, 784.17, 784.18, 784.19, 784.20, 784.21, 784.22, 784.23, 784.24, 784.25, 784.26; R645-301-231, -301-233, -301-322, -301-323, -301-331, -301-333, -301-341, -301-342, -301-411, -301-412, -301-422, -301-512, -301-513, -301-521, -301-522, -301-525, -301-526, -301-527, -301-528, -301-529, -301-531, -301-533, -301-534, -301-536, -301-537, -301-542, -301-623, -301-624, -301-625, -301-626, -301-631, -301-632, -301-731, -301-723, -301-724, -301-725, -301-726, -301-728, -301-729, -301-731, -301-732, -301-733, -301-746, -301-764, -301-830.

Analysis:

The transmission lines will be removed, conductor cables removed, and the wood poles cut off at ground level. The Division has approved this method at several mines.

Findings:

The permittee has met the minimum requirements of this section.

TOPSOIL AND SUBSOIL

Regulatory Reference: 30 CFR Sec. 817.22; R645-301-240.

Analysis:

Redistribution

There will be no redistribution of topsoil to the power line corridor. The total disturbance of 38 power poles will be 0.002 acres.

TECHNICAL MEMO

Findings:

The permittee has met the minimum requirements of this section.

REVEGETATION

Regulatory Reference: 30 CFR Sec. 785.18, 817.111, 817.113, 817.114, 817.116; R645-301-244, -301-353, -301-354, -301-355, -301-356, -302-280, -302-281, -302-282, -302-283, -302-284.

Analysis:

General requirements

There will be no revegetation of this area since the power poles will be cut-off at ground level. However, in the event that the area is disturbed, the permittee will reclaim the disturbance by the approved plan.

Findings:

The permittee has met the minimum requirements of this section.

BONDING AND INSURANCE REQUIREMENTS

Regulatory Reference: 30 CFR Sec. 800; R645-301-800, et seq.

Analysis:

Determination of bond amount

The permittee has shown a \$19,600 increase in the bond for the reclamation of the power line to the 4th East portals. The permittee has sufficient bond due to the fact the preparation plant has never been constructed.

Findings:

The permittee has met the minimum requirements of this section.

RECOMMENDATIONS:

This amendment is recommended for approval. The permittee has met the minimum requirements.