

STATE OF UT.
DEPARTMENT OF HEALTH
DIVISION OF ENVIRONMENTAL HEALTH
150 West North Temple, P.O. Box 2500, Salt Lake City, Utah 84110-2500



Alvin E. Rickers, Director
Room 474 801-533-6121

James O. Mason, M.D., Dr.P.H.
Executive Director
801-533-6111

May 21, 1982
533-6146

- DIVISIONS
- Community Health Services
 - Environmental Health
 - Family Health Services
 - Health Care Financing
- OFFICES
- Administrative Services
 - Community Health Nursing
 - Management Planning
 - Medical Examiner
 - State Health Laboratory

Merrill Heward
Manager of Mining and Exploration
Utah Power and Light Company
P.O. Box 899
Salt Lake City, Utah 84110

RECEIVED
MAY 24 1982
WATER RIGHTS

RE: Des-Bee-Dove
Sanitary System

Dear Mr. Heward:

I have reviewed the 1981 Utah Power and Light Des-Bee-Dove Coal Mine permit application. Section 3 - page 29 indicates a 2500 gallon septic tank and drainfield was installed to treat the wastewater from the office and bathhouse. As search of our files fails to indicate that the system was approved by this office. Therefore we would appreciate receiving information sufficient to indicate that the system complies with the State Wastewater Disposal Regulations.

In addition there should be a discussion of a spill prevention control plan for the diesel and gasoline storage. The information should indicate methods used to contain spills. Spills must be reported immediately to this office 24 hour response number 533-6145.

The sediment pond for control of surface runoff was approved by our office and there is a current NPDES permit for this facility.

A prompt response concerning the information will be appreciated.

RECEIVED

MAY 28 1982

Sincerley,

Steven McNeal
Public Health Engineer
Bureau of Water Pollution Control

DIVISION OF
OIL, GAS & MINING

SM:ddr
cc: Dennis Dalley
Oil, Gas and Mining
Southeast District Health Department
Southeast AOG

1263