



Norman H. Bangerter
Governor

Suzanne Dandoy, M.D., M.P.H.
Executive Director

August 14, 1986

RECEIVED
AUG 18 1986

D. Wayne Hedberg
Permit Supervisor
Division of Oil, Gas, & Mining
3 Triad Center - Suite 350
355 West North Temple
Salt Lake City, Utah 84180-1203

**DIVISION OF
OIL, GAS & MINING**

Dear Mr. Hedberg:

RE: Deer Creek Mine - Industrial Process
Water

As per your August 5 letter, we have reviewed the MRP Amendment for the referenced facilities and have concluded this office has no regulatory or environmental concerns on the proposal. This is based on information supplied from yours and Utah Power & Light Company's offices. This indicates the project is to consist of redeveloping a dust and fire suppression water system. It was stated that these facilities will have no direct connection to the culinary water system.

However, please note that if any of this changes, the Utah Public Drinking Water Regulations require complete plans and specifications be approved prior to commencing construction. We appreciate the opportunity to comment, and should you have further questions, please contact this office.

Sincerely,

Michael B. Georgeson
Manager, Pre-Construction Program
Bureau of Drinking Water/Sanitation
(801) 538-6159

LJM:md
2742T

cc: Utah Power & Light Company, Salt Lake City Mining Division
Bureau of Water Pollution Control
Dave Ariotti