



STATE OF UTAH
DEPARTMENT OF HEALTH

File ACT/015/032
Folder #3,4
Copy to Sec, Wayne
NORMAN H. BANGERTE, GOVERNOR

SUZANNE DANDOO, M.D., M.P.H., EXECUTIVE DIRECTOR

October 24, 1985
533-6146

RECEIVED

OCT 28 1985

DIVISION OF OIL
GAS & MINING

Mr. Charles H. Gent Jr.
Genwal Coal Company, Inc.
P. O. Box 1201
Huntington, Utah 84528

Re Construction Permit
Sediment Pond Revision

Dear Mr. Gent:

We have reviewed the plans and information for the Genwal Coal Crandall Canyon sediment pond revisions. The August 5, 1985 report by Earthfax Engineering, Inc. including plate 2 was reviewed.

As a result of our review it has been determined that the sediment pond revisions basically conform with the State Wastewater Disposal Regulations. This letter constitutes a construction permit subject to the following condition:

An oil skimming device extending at least four inches below the decant pipe is included.

The pond revisions include raising the dike elevation by two feet and the riser spillway by 3.8 feet. The decant pipe will be raised 1.5 feet and is to be at least two feet above the sediment clean out level. Dike slopes are to be 2 horizontal to 1 vertical and dike crest width of 10 feet.

If the discharge fails to meet State or Federal discharge limitations additional treatment must be provided. In addition any chemical treatment of roads must be approved by this office prior to use. Additional information on the chemicals to be used and potential salinity impact would need to be submitted.

Sincerely,

UTAH WATER POLLUTION CONTROL COMMITTEE

Jay B. Pittman
Calvin K. Sudweeks
Executive Secretary

cc: Oil, Gas and Mining
Southeastern Dist. Health Dept.
Southeastern Dist. Engineer

388
SRM:pa

KENNETH L. ALKEMA, DIRECTOR • DIVISION OF ENVIRONMENTAL HEALTH