

**OGMCOAL - Minor edits to Crandall treatment plan**

---

**From:** Kevin Lundmark  
**To:** Dave Shaver; OGMCOAL; Steve Christensen  
**Date:** 12/21/2009 1:37 PM  
**Subject:** Minor edits to Crandall treatment plan

---

Dave,

During my review of your December 2 submittal for the Crandall treatment facility I found a few typos/errors that I'd like to pass along to your attention. These did not warrant inclusion as deficiencies, but could be corrected in a future submittal.

Appendix 7-65

page 2, 2nd paragraph - change to "..is constructed from 12" thick pre-existing concrete wall" (not 12')

page 3, bottom line - change to "booms" (not boons)

page 6, 1st full paragraph, last sentence - should be 10 yr-24 hr precipitation event (not 25 hr).

page 13, number 4), third sentence - delete "(freeboard)". The freeboard, defined by the spillway elevation relative to the top of embankment elevation, will not vary during operation.

page 17, 4th paragraph - Delete "sufficient freeboard for" from sentence.

Thanks,  
Kevin

Kevin Lundmark  
Environmental Scientist  
Division of Oil, Gas & Mining  
(801)538-5352