



Final Results

Report To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM (WT1177)
1594 W NORTH TEMPLE-SUITE 1210
Salt Lake City, UT 84114

Bill To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM
1594 W NORTH TEMPLE-SUIT 1210
Salt Lake City, UT 84114

Project ID: C2019-00801

Steve Christensen,

Your sample(s) submitted to Utah Public Health Laboratory (UPHL) on Thursday, March 21, 2019 were assigned the UPHL Project ID **C2019-00801**. Enclosed are the analytical results pertaining to that Project ID.

Herein are the results relating only to the sample(s) received and tested for the project C2019-00801. All associated analyses were performed following the UPHL Quality Assurance Plan. This report and its contents have been reviewed and approved by the appropriate Laboratory Staff and Supervisor(s). This report shall not be reproduced, except in full, without the written permission of UPHL.

If you have any questions regarding your results, please contact UPHL at (801) 965-2400 and reference the Project ID C2019-00801.

A handwritten signature in black ink, appearing to read 'Kyle Ashby', written over a horizontal line.

Reviewed by: Kyle Ashby
Reviewed on: 4/9/2019



Project Summary

Report To:

Steve Christensen (WT1177)
DEPT OF NATURAL RESOURCES-OGM (WT1177)
1594 W NORTH TEMPLE-SUITE 1210
Salt Lake City, UT 84114

Bill To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM
1594 W NORTH TEMPLE-SUIT 1210
Salt Lake City, UT 84114

Phone: 801-538-5262

Fax: 801-359-3940

E-mail: stevechristensen@utah.gov

Phone: 801-538-5262

Fax: 801-539-3940

E-mail: stevechristensen@utah.gov

Project ID: C2019-00801

<u>Sample #</u>	<u>Date Collected</u>	<u>Date Received</u>	<u>Facility</u>	<u>Sampling Point</u>	<u>Site Description</u>
2175221	03/20/19	03/21/19	N/A	N/A	002
2175223	03/20/19	03/21/19	N/A	N/A	002

Facility: N/A Sampling Point: N/A Site Description: 002	
Sample ID: 2175221 Text ID: TCH19-0393 Matrix: Water Bottle Type: Total Chemistry - 1 L unpreserved plastic SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - EPA 375.2

Analyzed By: Keith Henderson Analysis Date: 04/04/2019 Analysis Batch: EPA375.2-20190404-1 Instrument ID: CHM_LACHAT_02	Reviewed By: Boyd Neilson Reviewed Date: 04/08/2019 Prep Method: Prep Batch: Prep Date:														
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Sulfate</td> <td>137 mg/L</td> <td>1</td> <td></td> <td>9.04 mg/L</td> <td>20.00 mg/L</td> <td>20.0 mg/L</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Sulfate	137 mg/L	1		9.04 mg/L	20.00 mg/L	20.0 mg/L	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL									
Sulfate	137 mg/L	1		9.04 mg/L	20.00 mg/L	20.0 mg/L									

Facility: N/A Sampling Point: N/A Site Description: 002	
Sample ID: 2175223 Text ID: UFL19-0096 Matrix: Water, Non-filtered Bottle Type: UnFiltered water for Drinking Water SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - Turbidity for Metals

Analyzed By: Stefan Liao Analysis Date: 03/21/2019 Analysis Batch: EPA180.1_M-20190321-1 Instrument ID:	Reviewed By: Kyle Ashby Reviewed Date: 03/21/2019 Prep Method: Prep Batch: Prep Date:														
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Turbidity</td> <td><1 NTU</td> <td>1</td> <td></td> <td>.5 NTU</td> <td>1.0 NTU</td> <td>1.0 NTU</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Turbidity	<1 NTU	1		.5 NTU	1.0 NTU	1.0 NTU	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL									
Turbidity	<1 NTU	1		.5 NTU	1.0 NTU	1.0 NTU									

Analysis Method - EPA 200.8

Analyzed By: Robert Lo Analysis Date: 03/22/2019 Analysis Batch: EPA200.8-20190322-1 Instrument ID: CHM_AGILENT_7700	Reviewed By: Stefan Liao Reviewed Date: 03/26/2019 Prep Method: Prep Batch: Prep Date:																					
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Selenium</td> <td><1.00 µg/L</td> <td>1.00</td> <td>U</td> <td>0.5 µg/L</td> <td>1 µg/L</td> <td>1.0 µg/L</td> </tr> <tr> <td>Aluminum</td> <td><10.0 µg/L</td> <td>1.00</td> <td>U</td> <td>5 µg/L</td> <td>10 µg/L</td> <td>10.0 µg/L</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Selenium	<1.00 µg/L	1.00	U	0.5 µg/L	1 µg/L	1.0 µg/L	Aluminum	<10.0 µg/L	1.00	U	5 µg/L	10 µg/L	10.0 µg/L	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL																
Selenium	<1.00 µg/L	1.00	U	0.5 µg/L	1 µg/L	1.0 µg/L																
Aluminum	<10.0 µg/L	1.00	U	5 µg/L	10 µg/L	10.0 µg/L																



Analytical Report

Project ID: C2019-00801

Facility: N/A Sampling Point: N/A Site Description: 002	
Sample ID: 2175223 (Continued) Text ID: UFL19-0096 Matrix: Water, Non-filtered Bottle Type: UnFiltered water for Drinking Water SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - EPA 200.8

Analyzed By: Robert Lo Analysis Date: 03/21/2019 Analysis Batch: EPA200.8_M-20190322-1 Instrument ID: CHM_AGILENT_7700	Reviewed By: Stefan Liao Reviewed Date: 03/22/2019 Prep Method: Prep Batch: Prep Date:
---	--

Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL
Iron	794 µg/L	1.00		15 µg/L	30 µg/L	30.0 µg/L

Report Comments

This report contains only the results for analyses requested and tested.

Unless otherwise noted:

- Samples were received in acceptable condition.
- Samples have not been blank corrected.
- All Quality Control Samples processed yielded acceptable results.

Report Symbol Definitions

MDL - Method Detection Limit, a statistically estimated concentration for instrument/method/matrix sensitivity.

MRL - Method Reporting Limit, the minimum concentration that can be reported as a quantitated value.

SRL - Sample Reporting Limit, the minimum concentration that can be reported as a quantitated value taking into account limitations inherent in the sample matrix.

ND - Not Detected, tested result was not detected above MDL or MRL.

< - Less than, tested result is less than the numerical value.

U - Not detected/reported



Final Results

Report To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM (WT1177)
1594 W NORTH TEMPLE-SUITE 1210
Salt Lake City, UT 84114

Bill To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM
1594 W NORTH TEMPLE-SUIT 1210
Salt Lake City, UT 84114

Project ID: C2019-00802

Steve Christensen,

Your sample(s) submitted to Utah Public Health Laboratory (UPHL) on Thursday, March 21, 2019 were assigned the UPHL Project ID **C2019-00802**. Enclosed are the analytical results pertaining to that Project ID.

Herein are the results relating only to the sample(s) received and tested for the project C2019-00802. All associated analyses were performed following the UPHL Quality Assurance Plan. This report and its contents have been reviewed and approved by the appropriate Laboratory Staff and Supervisor(s). This report shall not be reproduced, except in full, without the written permission of UPHL.

If you have any questions regarding your results, please contact UPHL at (801) 965-2400 and reference the Project ID C2019-00802.

A handwritten signature in black ink, appearing to read 'Kyle Ashby', written over a horizontal line.

Reviewed by: Kyle Ashby
Reviewed on: 4/9/2019



Project Summary

Report To:

Steve Christensen (WT1177)
DEPT OF NATURAL RESOURCES-OGM (WT1177)
1594 W NORTH TEMPLE-SUITE 1210
Salt Lake City, UT 84114

Bill To:

Steve Christensen
DEPT OF NATURAL RESOURCES-OGM
1594 W NORTH TEMPLE-SUIT 1210
Salt Lake City, UT 84114

Phone: 801-538-5262

Fax: 801-359-3940

E-mail: stevechristensen@utah.gov

Phone: 801-538-5262

Fax: 801-539-3940

E-mail: stevechristensen@utah.gov

Project ID: C2019-00802

<u>Sample #</u>	<u>Date Collected</u>	<u>Date Received</u>	<u>Facility</u>	<u>Sampling Point</u>	<u>Site Description</u>
2175222	03/20/19	03/21/19	N/A	N/A	PRE-002
2175224	03/20/19	03/21/19	N/A	N/A	PRE-002

Facility: N/A Sampling Point: N/A Site Description: PRE-002	
Sample ID: 2175222 Text ID: TCH19-0394 Matrix: Water Bottle Type: Total Chemistry - 1 L unpreserved plastic SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - EPA 375.2

Analyzed By: Keith Henderson Analysis Date: 04/04/2019 Analysis Batch: EPA375.2-20190404-1 Instrument ID: CHM_LACHAT_02	Reviewed By: Boyd Neilson Reviewed Date: 04/08/2019 Prep Method: Prep Batch: Prep Date:														
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Sulfate</td> <td>135 mg/L</td> <td>1</td> <td></td> <td>9.04 mg/L</td> <td>20.00 mg/L</td> <td>20.0 mg/L</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Sulfate	135 mg/L	1		9.04 mg/L	20.00 mg/L	20.0 mg/L	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL									
Sulfate	135 mg/L	1		9.04 mg/L	20.00 mg/L	20.0 mg/L									

Facility: N/A Sampling Point: N/A Site Description: PRE-002	
Sample ID: 2175224 Text ID: UFL19-0097 Matrix: Water, Non-filtered Bottle Type: UnFiltered water for Drinking Water SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - Turbidity for Metals

Analyzed By: Stefan Liao Analysis Date: 03/21/2019 Analysis Batch: EPA180.1_M-20190321-1 Instrument ID:	Reviewed By: Kyle Ashby Reviewed Date: 03/21/2019 Prep Method: Prep Batch: Prep Date:														
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Turbidity</td> <td><1 NTU</td> <td>1</td> <td></td> <td>.5 NTU</td> <td>1.0 NTU</td> <td>1.0 NTU</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Turbidity	<1 NTU	1		.5 NTU	1.0 NTU	1.0 NTU	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL									
Turbidity	<1 NTU	1		.5 NTU	1.0 NTU	1.0 NTU									

Analysis Method - EPA 200.8

Analyzed By: Robert Lo Analysis Date: 03/22/2019 Analysis Batch: EPA200.8-20190322-1 Instrument ID: CHM_AGILENT_7700	Reviewed By: Stefan Liao Reviewed Date: 03/26/2019 Prep Method: Prep Batch: Prep Date:														
<table border="1"> <thead> <tr> <th>Analyte</th> <th>Result</th> <th>Dil Fac</th> <th>Qualifier</th> <th>MDL</th> <th>MRL</th> <th>SRL</th> </tr> </thead> <tbody> <tr> <td>Selenium</td> <td><1.00 µg/L</td> <td>1.00</td> <td>U</td> <td>0.5 µg/L</td> <td>1 µg/L</td> <td>1.0 µg/L</td> </tr> </tbody> </table>	Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL	Selenium	<1.00 µg/L	1.00	U	0.5 µg/L	1 µg/L	1.0 µg/L	
Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL									
Selenium	<1.00 µg/L	1.00	U	0.5 µg/L	1 µg/L	1.0 µg/L									

Facility: N/A Sampling Point: N/A Site Description: PRE-002	
Sample ID: 2175224 (Continued) Text ID: UFL19-0097 Matrix: Water, Non-filtered Bottle Type: UnFiltered water for Drinking Water SDWIS Type: Private Investigative	Date Collected 3/20/2019 11:00:00AM Collected By: JE COC Initiated: Yes Condition of Seal: Not Present

Analysis Method - EPA 200.8

Analyzed By: Robert Lo Analysis Date: 03/21/2019 Analysis Batch: EPA200.8_M-20190322-1 Instrument ID: CHM_AGILENT_7700	Reviewed By: Stefan Liao Reviewed Date: 03/22/2019 Prep Method: Prep Batch: Prep Date:
---	--

Analyte	Result	Dil Fac	Qualifier	MDL	MRL	SRL
Iron	890 µg/L	1.00		15 µg/L	30 µg/L	30.0 µg/L

Report Comments

This report contains only the results for analyses requested and tested.

Unless otherwise noted:

- Samples were received in acceptable condition.
- Samples have not been blank corrected.
- All Quality Control Samples processed yielded acceptable results.

Report Symbol Definitions

MDL - Method Detection Limit, a statistically estimated concentration for instrument/method/matrix sensitivity.

MRL - Method Reporting Limit, the minimum concentration that can be reported as a quantitated value.

SRL - Sample Reporting Limit, the minimum concentration that can be reported as a quantitated value taking into account limitations inherent in the sample matrix.

ND - Not Detected, tested result was not detected above MDL or MRL.

< - Less than, tested result is less than the numerical value.

U - Not detected/reported