

Mic file
D. Haddock RB

0020



Southern Utah Fuel Company

a subsidiary of The Coastal Corporation
P.O. Box P • Salina, Utah 84654 • (801) 529-7428
Mine: (801) 637-4880

April 20, 1990

RECEIVED
APR 25 1990

DIVISION OF
OIL, GAS & MINING

Director
U.S. Environmental Protection Agency
Water Management Division (8WM-C)
1 Denver Place, Suite 500
999 18th Street
Denver, CO 80202-2413

Dear Director:

In accordance with Part II-I-3 of our NPDES Permit UT0022918 and UMC 817.52(b)(1)(ii), we are notifying you of a noncompliance sample for our NPDES Discharge Point 003.

The sample collected April 6, 1990 had a reported TDS level of 814 mg/l. This TDS value is 14 mg/l above the maximum allowable permit level of 800 mg/l. A copy of the laboratory analysis is enclosed. This sample was taken as part of our regular NPDES monitoring.


Sincerely,
SOUTHERN UTAH FUEL COMPANY

Wesley K. Sorensen, P.E.
Chief Engineer

WKS:wks

Enclosure

xc: Keith Welch - CSEC
Lowell Braxton - DOGM
Patty Winslow - DOH



Ford Chemical

LABORATORY, INC.

Bacteriological and Chemical Analysis

40 WEST LOUISE AVENUE
SALT LAKE CITY, UTAH 84115

PHONE 466-8761

RECEIVED

APR 19 1990

SOUTHERN UTAH
FUEL COMPANY

DATE: 04/17/90

CERTIFICATE OF ANALYSIS

*SOUTHERN UTAH FUEL
ATTN: CHRIS KRAVITS
P.O. BOX F
SALINA, UTAH 84654

90-005811

SAMPLE: WATER SAMPLE #PT003040690 FROM EFFLUENT PT. 003 COLLECTED
4-6-90, 9:30 AM BY C. KRAVITS RECEIVED 4-6-90 FOR ANALYSIS
STARTING AT 1:30 PM UNDER S.O. #6016.

RESULTS

Iron, Fe (Tot) mg/l SM303A	<.03
Oil and Grease mg/l EPA 413.1	1.0
Suspended Solids mg/l EPA 160.2	<1
Tot. Dis. Solids mg/l EPA 160.1	814
pH Units EPA 150.1	7.20

R. Luis
FORD CHEMICAL LABORATORY, INC.