



Coastal
The Energy People

Baron route to mine file
041/002 #2 + 6

March 9, 1992

Utah Department of Health
Bureau of Water Pollution Control
Attn: Compliance Officer
P.O. Box 16690
Salt Lake City, UT 84116-0690

Dear Compliance Officer:

Southern Utah Fuel Company experienced a non-compliance discharge with respect to total suspended solids at outflow 002 for the February monthly and weekly averages. The monthly average exceeded the permit limit of 25 by 5 mg/l. The weekly average exceeded the permit limit of 35 by 1 mg/l. A non-compliance discharge with respect to total dissolved solids on a monthly average for outflow 003 was also experienced during February. The average monthly TDS permit limit of 800 was exceeded by 56 mg/l.

Sincerely,
SOUTHERN UTAH FUEL COMPANY


Wesley K. Sorensen, P.E.
Chief Engineer

WKS:jad#279

xc:
Lowell Braxton - DOGM
Keith Welch -Coastal

RECEIVED

MAR 13 1992

DIVISION OF
OIL GAS & MINING

Southern Utah Fuel Company

A SUBSIDIARY OF THE COASTAL CORPORATION
397 SOUTH 800 WEST • SALINA UT 84654 • 801.637-4880