




Coastal
The Energy People

Scam - results file
04/002 #2



June 1, 1992

Mr. Don Ostler, Bureau Director
State of Utah
Division of Water Quality
Department of Environmental Quality
288 North 1460 West
Salt Lake City, Utah 84116-4870

RE: NPDES PERMIT UT-0022918

Dear Mr. Ostler:

In accordance with the conditions of NPDES Discharge Permit UT-0022918, Part II-I-3 and Utah Coal Mining Rules R645-301-731.223, Southern Utah Fuel Company is herewith providing the written notification of a failure to comply with the maximum effluent limitations for TDS at outfall 003.

The monthly average for TDS concentration of 849 mg/l exceeds the 800 mg/l limitation established in the current NPDES discharge permit. The May 6, 1992 sample had a TDS value of 901 while the May 20, 1992 sample had a TDS value of 796. The May 20, 1992 laboratory report was received on May 29, 1992.

Sincerely,
SOUTHERN UTAH FUEL COMPANY

Wesley K. Sorensen, P.E.
Chief Engineer

WKS:jad#308

xc: Division of Oil, Gas & Mining
Michael Reed, EPA
Keith Welch
Ken Payne
Kerry Frame

Southern Utah Fuel Company

A SUBSIDIARY OF THE COASTAL CORPORATION
397 SOUTH 800 WEST • SALINA UT 84654 • 801/637-4880