

*mine file***RECEIVED**

OCT 23 1992

DIVISION OF  
OIL GAS & MINING

October 20, 1992

Mr. Don Ostler, Bureau Director  
State of Utah  
Division of Water Quality  
Department of Environmental Quality  
288 North 1460 West  
Salt Lake City, Utah 84116-4870

RE: NPDES PERMIT UT-0022918

Dear Mr. Ostler:

In accordance with the conditions of NPDES Discharge Permit UT-0022918, Part II-I-3 and Utah Coal Mining Rules R645-301-731.223, Southern Utah Fuel Company is herewith providing the written notification of a failure to comply with the maximum effluent limitations for TDS at outfall 003.

The monthly average for TDS concentration of 825 mg/l exceeds the 800 mg/l limitation established in the current NPDES discharge permit. The September 11, 1992 sample had a TDS value of 820 mg/l. The September 28, 1992 sample had a TDS value of 830 mg/l.

Sincerely,  
SOUTHERN UTAH FUEL COMPANY

Wesley K. Sorensen, P.E.  
Chief Engineer

WKS:jad#355

xc: Division of Oil, Gas & Mining  
Michael Reed, EPA  
Keith Welch  
Ken Payne  
Kerry Frame